


9 February 2022

Report to Queensland Competition Authority

# Estimated energy costs

For use by the Queensland Competition Authority in its Draft Determination of 2022-23 retail electricity tariffs



## About ACIL Allen

ACIL Allen is a leading independent economics, policy and strategy advisory firm, dedicated to helping clients solve complex issues.

Our purpose is to help clients make informed decisions about complex economic and public policy issues.

Our vision is to be Australia's most trusted economics, policy and strategy advisory firm. We are committed and passionate about providing rigorous independent advice that contributes to a better world.

### Suggested citation for this report

Estimated energy costs for 2022-23 retail electricity tariffs: Draft Determination, ACIL Allen, February 2022

**Reliance and disclaimer** The professional analysis and advice in this report has been prepared by ACIL Allen for the exclusive use of the party or parties to whom it is addressed (the addressee) and for the purposes specified in it. This report is supplied in good faith and reflects the knowledge, expertise and experience of the consultants involved. The report must not be published, quoted or disseminated to any other party without ACIL Allen's prior written consent. ACIL Allen accepts no responsibility whatsoever for any loss occasioned by any person acting or refraining from action as a result of reliance on the report, other than the addressee.

In conducting the analysis in this report ACIL Allen has endeavoured to use what it considers is the best information available at the date of publication, including information supplied by the addressee. ACIL Allen has relied upon the information provided by the addressee and has not sought to verify the accuracy of the information supplied. If the information is subsequently determined to be false, inaccurate or incomplete then it is possible that our observations and conclusions as expressed in this report may change. The passage of time, manifestation of latent conditions or impacts of future events may require further examination of the project and subsequent data analysis, and re-evaluation of the data, findings, observations and conclusions expressed in this report. Unless stated otherwise, ACIL Allen does not warrant the accuracy of any forecast or projection in the report. Although ACIL Allen exercises reasonable care when making forecasts or projections, factors in the process, such as future market behaviour, are inherently uncertain and cannot be forecast or projected reliably.

This report does not constitute a personal recommendation of ACIL Allen or take into account the particular investment objectives, financial situations, or needs of the addressee in relation to any transaction that the addressee is contemplating. Investors should consider whether the content of this report is suitable for their particular circumstances and, if appropriate, seek their own professional advice and carry out any further necessary investigations before deciding whether or not to proceed with a transaction. ACIL Allen shall not be liable in respect of any claim arising out of the failure of a client investment to perform to the advantage of the client or to the advantage of the client to the degree suggested or assumed in any advice or forecast given by ACIL Allen.

# Contents

1	Introduction	5
2	Overview of approach	6
2.1	Introduction	6
2.2	Components of the total energy cost estimates	6
2.3	Methodology	7
3	Responses to submissions to Interim consultation paper	21
3.1	Ex-post assessment of the WEC	21
3.2	Availability of cap contracts	24
3.3	Price shape	25
3.4	Load shape	26
3.5	NEM fees	26
4	Estimation of energy costs	28
4.1	Introduction	28
4.2	Estimation of the Wholesale Energy Cost	33
4.3	Estimation of renewable energy policy costs	47
4.4	Estimation of other energy costs	50
4.5	Estimation of energy losses	55
4.6	Summary of estimated energy costs	57
A	AEMC 2021 Residential electricity price trends report	A-1
A.1	Wholesale energy costs	A-1
Figures		
<b>Figure 2.1</b>	Components of TEC	7
<b>Figure 2.2</b>	Illustrative example of hedging strategy, prices and costs	9
<b>Figure 2.3</b>	Estimating the WEC – market-based approach	14
<b>Figure 2.4</b>	Steps to estimate the cost of LRET	18
<b>Figure 2.5</b>	Steps to estimate the cost of SRES	19
<b>Figure 3.1</b>	Daily settlement prices and trade volume weighted prices (\$/MWh) for Q1 base contracts in Queensland	23
<b>Figure 3.2</b>	Illustrative comparison of WEC estimation accuracy given contract market environment	24
<b>Figure 3.3</b>	Cumulative trade volumes of ASX Energy quarterly caps in Queensland	25
<b>Figure 3.4</b>	Simulated average time of day spot price (\$/MWh, nominal) for Queensland for 2022-23 compared with range of actual annual outcomes in past five years	26
<b>Figure 4.1</b>	Actual average time of day wholesale electricity spot price (\$/MWh, nominal) and load profiles (MW, relative) – Queensland – 2011-12 to 2020-21	31
<b>Figure 4.2</b>	Actual annual average demand weighted price (\$/MWh, nominal) by profile and Queensland time weighted average price (\$/MWh, nominal) – 2009-10 to 2020-21	32
<b>Figure 4.3</b>	Queensland Base, Peak, and Cap trade weighted average contract prices (\$/MWh, nominal) – 2013-14 to 2022-23	33
<b>Figure 4.4</b>	Time series of trade volume and price – ASX Energy base futures - Queensland	34

# Contents

<b>Figure 4.5</b>	Time series of trade volume and price – ASX Energy peak futures - Queensland	35
<b>Figure 4.6</b>	Time series of trade volume and price – ASX Energy \$300 cap futures - Queensland	36
<b>Figure 4.7</b>	Comparison of upper one per cent of hourly loads of 2022-23 simulated hourly demand sets with historical outcomes – Queensland	37
<b>Figure 4.8</b>	Comparison of upper one per cent of hourly loads and load factors of 2022-23 simulated hourly demand sets with historical outcomes – Energex NSLP	38
<b>Figure 4.9</b>	Comparison of various metrics of hourly prices from the 2022-23 simulations with historical outcomes – Queensland	39
<b>Figure 4.10</b>	Simulated annual DWP for Energex NSLP as percentage premium of annual TWP for 2022-23 compared with range of actual outcomes in past years	40
<b>Figure 4.11</b>	Contract volumes used in hedge modelling of 561 simulations for 2022-23 for Energex NSLP	42
<b>Figure 4.12</b>	Annual hedged price and DWP (\$/MWh, nominal) for Energex NSLP for the 561 simulations – 2022-23	43
<b>Figure 4.13</b>	Estimated WEC (\$/MWh, nominal) for 2022-23 at the regional reference node in comparison with WECs from previous determinations	44
<b>Figure 4.14</b>	Comparison of time weighted spot prices, base contract prices, demand weighted spot prices, WECs (\$/MWh, nominal) – Energex NSLP	46
<b>Figure 4.15</b>	LGC prices for 2022 and 2023 for 2022-23 (\$/LGC, nominal)	48
<b>Figure A.1</b>	Total wholesale costs (\$/MWh, nominal)	A-2
<b>Tables</b>		
<b>Table 2.1</b>	Sources of load data	10
<b>Table 3.1</b>	Review of issues raised in submissions in response to the Interim consultation paper	21
<b>Table 4.1</b>	Estimated contract prices (\$/MWh, nominal) - Queensland	33
<b>Table 4.2</b>	Estimated WEC (\$/MWh, nominal) for 2022-23 at the regional reference node	43
<b>Table 4.3</b>	Estimating the 2022 and 2023 RPP values	48
<b>Table 4.4</b>	Estimated cost of LRET – 2022-23	49
<b>Table 4.5</b>	Estimated cost of SRES – 2022-23	49
<b>Table 4.6</b>	Total renewable energy policy costs (\$/MWh, nominal) – 2022-23	49
<b>Table 4.7</b>	NEM management fees (\$/MWh, nominal) – 2022-23	50
<b>Table 4.8</b>	Ancillary services (\$/MWh, nominal) – 2022-23	50
<b>Table 4.9</b>	AEMO prudential costs for Energex NSLP – 2022-23	52
<b>Table 4.10</b>	AEMO prudential costs for Ergon NSLP – 2022-23	52
<b>Table 4.11</b>	Hedge Prudential funding costs by contract type – Queensland 2022-23	53
<b>Table 4.12</b>	Hedge Prudential funding costs for ENERGEX NSLP – 2022-23	53
<b>Table 4.13</b>	Hedge Prudential funding costs for ERGON NSLP – 2022-23	54
<b>Table 4.14</b>	Total prudential costs (\$/MWh, nominal) – 2022-23	54
<b>Table 4.15</b>	Total of other costs (\$/MWH, nominal) – Energex NSLP – 2022-23	55
<b>Table 4.16</b>	total of other costs (\$/MWH, nominal) – Ergon NSLP – 2022-23	55
<b>Table 4.17</b>	Estimated transmission and distribution losses	56
<b>Table 4.18</b>	Estimated TEC for 2022-23 Draft Determination	57



ACIL Allen has been engaged by the Queensland Competition Authority (the QCA) to provide advice on the energy related costs likely to be incurred by a retailer to supply customers on notified retail prices for the 2022-23 regulatory period.

Retail prices generally consist of three components:

- network costs
- energy costs
- costs associated with retailing to end users.

ACIL Allen's engagement relates to the energy costs component only. In accordance with the Ministerial Delegation (the Delegation), and the Consultancy Terms of Reference (TOR) provided by the QCA, the methodology developed by ACIL Allen provides an estimate of energy costs to be incurred by a retailer to supply customers on notified prices for 2022-23. Although the QCA's determination is to apply only to the area outside of the Energex distribution area, the TOR specifically requests that ACIL Allen's analysis cover the same tariff classes as covered in the analysis for the 2021-22 determination, and therefore includes the load profiles for residential and small business customers in south east Queensland.

Hence, we are required to provide estimates for:

- Energex's net system load profile (NSLP)
- Ergon Energy's NSLP
- load control profiles for small customers in the Energex distribution area
- load control profiles for large business customers in the Ergon distribution area.

This report provides estimates of the energy costs for use by the QCA in its Draft Determination.

The report is presented as follows:

- Chapter 2 summarises our methodology.
- Chapter 3 provides responses to submissions made by various parties following the release of the QCA's *Interim Consultation Paper: Regulated retail electricity prices for 2022-23* (December 2021), where those submissions refer to the methodology used to estimate the cost of energy in regulated retail electricity prices.
- Chapter 4 summarises our derivation of the energy cost estimates.
- Finally, Appendix A summarises our high-level comparison with the AEMC's 2021 Residential Electricity Price Trends Report released in November 2021.



# Overview of approach

# 2

## 2.1 Introduction

---

In preparing advice on the estimated energy costs, ACIL Allen is required to have regard to the actual costs of making, producing or supplying the goods or services which in this case are the customer retail services to be supplied to customers on notified prices for the tariff year 1 July 2022 to 30 June 2023.

## 2.2 Components of the total energy cost estimates

---

ACIL Allen is required to estimate the Total Energy Costs (TEC) component of the retail tariffs. Total Energy Costs comprise of the following components (as shown in Figure 2.1):

- Wholesale energy costs (WEC) for various demand profiles
- Environmental Costs: costs of complying with state and federal government policies, including the Renewable Energy Target (RET).
- Other wholesale costs: including National Electricity Market (NEM) fees, ancillary services charges, Reliability and Emergency Reserve Trader (RERT) costs, and costs of meeting prudential requirements.
- Energy losses incurred during the transmission and distribution of electricity to customers.

**Figure 2.1** Components of TEC

Source: ACIL Allen

## 2.3 Methodology

ACIL Allen's methodology follows the methodology used to provide advice to the QCA for the 2013-14 to 2021-22 determinations.

The ACIL Allen methodology estimates costs from a retailing perspective. This involves estimating the energy and environmental costs that an electricity retailer would be expected to incur in a given determination year. The methodology includes undertaking wholesale energy market simulations to estimate expected spot market costs and volatility, and the hedging of the spot market price risk by entering into electricity contracts with prices represented by the observable futures market data. Environmental and other energy costs are added to the wholesale energy costs and the total is then adjusted for network losses.

### 2.3.1 Estimating the WEC - market-based approach

Energy purchase costs are incurred by a retailer when purchasing energy from the NEM spot market to satisfy their retail load. However, given the volatile nature of wholesale electricity spot prices, which is an important and fundamental feature of an energy-only market (i.e. a market without a separate capacity mechanism), and that retailers charge their customers based on fixed rate tariffs (for a given period), a prudent retailer is incentivised to hedge its exposure to the spot market.

Hedging can be achieved by a number of means – a retailer can own or underwrite a portfolio of generators (the gen-tailer model), enter into bilateral contracts directly with generators, purchase over the counter (OTC) contracts via a broker, or take positions on the futures market. Typically, a retailer will employ a number of these hedging approaches. In addition, a retailer may choose to leave a portion of their load exposed to the spot market.

At the core of the market-based approach is an assumed contracting strategy that an efficient retailer would use to manage its electricity market risks. Such risks and the strategy used to mitigate them are an important part of electricity retailing. The contracting strategy adopted generally assumes that the retailer is partly exposed to the wholesale spot market and partly protected by the procured contracts.

The methodology simulates the cost of hedging by building up a portfolio of hedges consisting of base and peak swap contracts, and cap contracts (and this is discussed in more detail below).

Conceptually, in a given half-hourly settlement period, the retailer:


- Pays AEMO the spot price multiplied by the demand.
- Pays the contract counterparty the difference between the swap contract strike price and the spot price, multiplied by the swap contract quantity. This is the case for the base swap contract regardless of time of day, and for the peak swap contract during the periods classified as peak. If the spot price is greater than the contract strike price then the counter party pays the retailer.
- Pays the contract counterparty the cap price multiplied by the cap contract quantity.
- If the spot price exceeds \$300/MWh, receives from the contract counter party the difference between the spot price and \$300, multiplied by the cap contract quantity.

Figure 2.2 shows an illustrative example of a hedging strategy for a given load across a 24-hour period.

In this example:

- The demand profile:
  - Varies between 400 MW and 1,300 MW.
  - Peaks between 6 pm and 10 pm, with a smaller morning peak between 9 am and 11 am.
- The hedging strategy:
  - Consists of 375 MW of base swaps, 100 MW of peak period swaps, and 700 MW of caps.
  - Means that demand exceeds the total of the contract cover between 7 pm and 10 pm by about 100 MW. Hence during these periods, the retailer is exposed to the spot price for 100 MW of the demand, and the remaining demand is covered by the hedges.
  - Demand is less than the hedging strategy for all other hours. Hence, during these periods the retailer in effect sells the excess hedge cover back to the market at the going spot price (and if the spot price is less than the contract price this represents a net cost to the retailer, and vice versa).

**Figure 2.2** Illustrative example of hedging strategy, prices and costs



Source: ACIL Allen

With this in mind, the WEC for a given demand profile for a given year is therefore generally a function of four components, the:

1. demand profile
2. wholesale electricity spot prices
3. forward contract prices
4. hedging strategy.

## Use of financial derivatives in estimating the WEC

As discussed above, retailers purchase electricity in the NEM at the spot price and use a number of strategies to manage their risk. Market-based approaches adopted by regulators for estimating the WEC make use of financial derivative data given that it is readily available and transparent. This is not to say regulators are of the view that retailers only use financial derivatives to manage risk – it simply reflects the availability and transparency of data.

Some retailers also use vertical integration and Power Purchase Agreements (PPAs) to manage their risk. However, the associated costs, terms and conditions of these approaches are not readily available in the public domain. Further, smaller retailers may not be in a position to use vertical integration or PPAs and hence rely solely on financial derivatives.

Additionally, the value of long-dated assets associated with vertical integration and PPAs is determined by conditions in the market at a given point in time. The price in a PPA or the annualised historical cost of generation reflects the long term value of the generation anticipated at the time of commitment when the investor was faced with a variety of uncertain futures. As a consequence, there are considerable difficulties in using the price of PPAs or the annualised historical cost of generation as a basis for estimating current hedging costs.

## Use of load profiles in estimating the WEC

The following load profiles are required for the given determination year:

- system load for each region of the NEM (that is, the load to be satisfied by scheduled and semi-scheduled generation) – used to model the regional wholesale electricity spot prices
- Net System Load Profiles (NSLPs) for the Energex and Ergon distribution networks
- controlled load profiles (CLPs) for small customers in the Energex distribution network
- CLPs for small business customers on a primary load control tariff in the Energex distribution network
- CLPs for large business customers in the Ergon distribution network.

Historical load data is available from AEMO – as shown in Table 2.1. The exception is the load data for the small business primary CLP in the Energex distribution network, which is derived from 2019-20 Ergon Energy Agricultural Tariff Trial data set<sup>1</sup>.

The NSLP is used as the representative load profile for residential and small business customers because the majority (about 80 per cent) of residential and small business customers in Queensland are on accumulation (or basic) meters. And those customers with digital (or interval) meters are in the minority. Therefore, a single WEC is estimated for residential and small business customers.

**Table 2.1** Sources of load data

Distribution Network	Load Type	Load	Source
NA	System Load	QLD1	MMS
Energex	NSLP	NSLP, ENERGEX	MSATS
Ergon	NSLP	NSLP, ERGON	MSATS
Energex	CLP – small customers	QLDEGXCL31, ENERGEX	MSATS

<sup>1</sup> Details of this data set and our treatment of it can be found in our report to the QCA as part of the 2020-21 Supplementary Pricing Review ([https://www.qca.org.au/wp-content/uploads/2020/10/rle\\_j0426-acil-allen-report-for-final-determination-28-sep-2020.pdf](https://www.qca.org.au/wp-content/uploads/2020/10/rle_j0426-acil-allen-report-for-final-determination-28-sep-2020.pdf)).

Distribution Network	Load Type	Load	Source
Energex	CLP – small customers	QLDEGXCL33, ENERGEX	MSATS
Energex	CLP – small business primary load control tariff	2019-20 Ergon Energy Agricultural Tariff Trial	Energy Queensland
Ergon	CLP – large business primary and secondary load control tariffs	QLDEGXCL33, ENERGEX	MSATS

Source: AEMO

### Key steps to estimating the WEC

The key steps to estimating the WEC for a given load and year are:

1. Forecast the hourly load profile – generally as a function of the underlying demand forecast as published by the Australian Energy Market Operator (AEMO), and accounting for further uptake of rooftop solar PV. A stochastic demand and renewable energy resource model to develop 51 weather influenced annual simulations of hourly demand and renewable energy resource traces which are developed so as to maintain the appropriate correlation between the various regional and NSLP/CLP demands, and various renewable energy zone resources.
2. Use a stochastic availability model to develop 11 annual simulations of hourly thermal power station availability.
3. Forecast hourly wholesale electricity spot prices by using ACIL Allen's proprietary wholesale energy market model, *PowerMark*. *PowerMark* produces 561 (i.e. 51 by 11) simulations of hourly spot prices of the NEM using the stochastic demand and renewable energy resource traces and power station availabilities as inputs.
4. Estimate the forward contract price using ASX Energy contract price data, verified with broker data. The book build is based on the observed trade volumes and the price estimate is equal to the trade volume weighted average price.
5. Adopt an assumed hedging strategy – the hedging strategy represents a strategy that a retailer would undertake to hedge against risk in the spot price in a given year. It is generally assumed that a retailer's risk management strategy would result in contracts being entered into progressively over a two- or three-year period, resulting in a mix (or portfolio) of base (or flat), peak and cap contracts.
6. Calculate the spot and contracting cost for each hour and aggregate for each of the 561 simulations – for a given simulation, for each hour calculate the spot purchase cost, contract purchase costs, and difference payments, and then aggregate to get an annual cost which is divided by the annual load to get a price in \$/MWh terms.

The above steps produce a distribution of estimated WECs which vary due to variations in demand, and spot prices. Wholesale electricity spot prices will vary depending on the actual load (which will vary based on weather conditions), renewable generator resource (which also varies with weather outcomes), and availability of thermal power stations. It is this variability, and associated risk, that incentivises retailers to enter into hedging arrangements. However, this variability also changes the values of the spot purchase costs and difference payments incurred by a retailer (even though the contract prices and strategy are fixed).

The distribution of outcomes produced by the above approach is then analysed to provide a risk assessed estimate of the WEC. ACIL Allen adopts the 95<sup>th</sup> percentile WEC from the distribution of WECs as the final estimate. In practice, the distribution of WECs from the simulations exhibits a relatively narrow spread when compared to estimates based on the load being 100 per cent exposed

to the spot market, which is to be expected since they are hedged values. Choosing the 95<sup>th</sup> percentile reduces the risk of understating the true WEC, since only five per cent of WEC estimates exceed this value.

### Choosing the appropriate hedging strategy

As mentioned above, multiple hedging strategies are tested by varying the mix of base/peak/cap contracts for each quarter. This is done by running the hedge model for a large number<sup>2</sup> of simulations for each strategy and analysing the resulting distribution of WECs for each given strategy – and in particular, keeping note of the 95<sup>th</sup> percentile WEC for each strategy. We select a strategy that is robust and plausible for each load profile, and minimises the 95<sup>th</sup> percentile WEC, noting that:

- some strategies may be effective in one year but not in others
- in practice, retailers do not necessarily make substantial changes to the strategy from one year to the next
- our approach is a simplification of the real world, and hence we are mindful not to over-engineer the approach and give a false sense of precision.

The hedging strategy is not necessarily varied for every determination year – it tends to change when there is a sufficient change in either the shape of the load profile (for example, due to the continued uptake of rooftop PV) or a change in the relationship between contract prices for the different contract products (for example, in some years base contract prices increase much more than peak contract prices, which can influence the strategy).

### Demand-side settings

The seasonal peak demand and annual energy forecasts for the regional demand profiles are referenced to the neutral scenarios from the latest available Electricity Statement of Opportunities (ESOO) published by AEMO and take into account past trends and relationships between the NSLPs and the corresponding regional demand.

It is usual practice to use a number of years of historical load data together with the P10, P50 and P90 seasonal peak load, and energy forecasts from the AEMO neutral scenario to produce multiple simulated representations of the hourly load profile for the given determination year using a Monte Carlo analysis. These multiple simulations include a mix of mild and extreme representations of demand – reflecting different annual weather conditions (such as mild, normal and hot summers).

The key steps in developing the demand profiles are:

- The half-hourly demand profiles of the past three years are obtained. The profiles are adjusted by ‘adding’ back the estimated rooftop PV generation for the system demand and each NSLP (based on the amount of rooftop PV in each distribution network).
- A stochastic demand model is used to develop about 51 weather influenced simulations of hourly demand traces for the NSLPs, each regional demand, and each renewable resource – importantly maintaining the correlation between each of these variables. The approach takes the past three years of actual demand data, as well as the past 51 years of weather data and uses a matching algorithm to produce 51 sets of weather-related demand profiles of 17,520 half-hourly loads. This approach does not rely on attempting to develop a statistical relationship between weather outcomes and demand – instead, it accepts there is a relationship and uses a matching algorithm to find the closest matching weather outcomes for a given day across the entire NEM from the past three years to represent a given day in the past.

<sup>2</sup> When testing the different strategies, we do not run the full set of 561 simulations as this is time prohibitive. However, we run the full set of 561 simulations once the strategy has been chosen.

- The set of 51 simulations of regional system demands is then grown to the AEMO demand forecast using a non-linear transformation so that the average annual energy across the 51 simulations equals the energy forecast, and the distribution of annual seasonal peak loads across the 51 simulations generally matches the distribution of peak loads inferred by the P10, P50 and P90 seasonal peaks from the AEMO demand forecast.
- A relationship between the variation in the NSLPs and the corresponding regional demand from the past four years is developed to measure the change in NSLP as a function of the change in regional demand. This relationship is then applied to produce 51 simulations of weather related NSLP profiles of 17,520 half-hourly loads which are appropriately correlated with system demand, but also exhibit an appropriate level of variation in the NSLP across the 51 simulations.
- The projected uptake of rooftop PV for the determination year is obtained (using our internal rooftop PV uptake model).
- The half-hourly rooftop PV output profile is then grown to the forecast uptake and deducted from the system demand and NSLPs.

### **Supply side settings**


ACIL Allen maintains a Reference case projection of the NEM, which it updates each quarter in response to supply changes announced in the market in terms of new investment, retirements, fuel costs, and plant availability. In this analysis, for 2022-23 we use our December 2021 Reference case projection settings which are closely aligned with AEMO's Integrated System Plan (ISP) for the Draft Determination, and we will use our latest reference case available at the time for the Final Determination.

ACIL Allen incorporates changes to existing supply where companies have formally announced the changes – including, mothballing, closure and change in operating approach. Near term new entrants are included where the plants are deemed by ACIL Allen to be committed projects.

### **Summary infographic of the approach to estimate the WEC**

Figure 2.3 provides an infographic type summary of the data, inputs, and flow of the market-based approach to estimating the WEC.

Figure 2.3 Estimating the WEC – market-based approach



### 2.3.2 Other wholesale costs

---

#### **Market fees and ancillary services costs**

Market fees and ancillary service costs are estimated based on data and policy documents published by AEMO.

#### ***NEM fees***

NEM fees are payable by retailers to AEMO to cover operational expenditure, costs associated with full retail contestability (FRC), the Energy Consumers Australia (ECA), DER, and IT upgrade costs associated with 5MS.

The approach used for estimating market fees is to make use of AEMO's budget report.

It is worth noting that in previous determinations, the National Transmission Planner (NTP) was included in this cost category. However, the recovery of this item has recently been transferred from AEMO to each of the Transmission Network Service Providers (TNSPs) directly, forming part of the TUOS charge. Therefore, the NTP cost is excluded from our analysis for 2022-23, just as it was for 2021-22.

#### ***Ancillary services charges***

Ancillary services charges cover the costs of services used by AEMO to manage power system safety, security and reliability. AEMO recovers the costs of these services from market participants. These fees are published by AEMO on its website on a weekly basis.

The approach used for estimating ancillary services costs is to average the most recent 52 weeks of costs to recover ancillary services from customers, which is published on the AEMO website. This is done on a region-by-region basis.

#### **Prudential costs**

Prudential costs, for AEMO, as well as representing the capital used to meet prudential requirements to support hedging take into account:

- the AEMO assessed maximum credit limit (MCL)
- the future risk-weighted spot price
- participant specific risk adjustment factors
- AEMO published volatility factors
- futures market prudential obligation factors, including:
  - the price scanning range (PSR)
  - the intra month spread charge
  - the spot isolation rate.

Prudential costs are calculated for each NSLP. The prudential costs for the NSLP are then used as a proxy for prudential costs for the controlled load profiles.

AEMO publishes volatility factors two years in advance. Similarly, ASX Energy publishes initial margin parameters two years in advance.

#### ***AEMO prudential costs***

AEMO calculates a maximum credit limit for each counterparty in order to determine the requirement for any or a combination of:

- bank guarantees

- reallocation certificates
- prepayment of cash.

There is no fundamental requirement to reallocate prudential obligations – it is a retailer’s choice to do so. Assuming no reallocation and no vertical integration (either owned generation or PPAs), a retailer is required to provide suitable guarantees to the AEMO assessed maximum credit limit (MCL) which is calculated as follows:

$$\text{MCL} = \text{OSL} + \text{PML}$$

Where for the Summer (December to March), Winter (May to August) and Shoulder (other months):

$$\text{OSL} = (\text{Average daily load} \times \text{Average future expected spot price} \times \text{Participant Risk Adjustment Factor} \times \text{OS Volatility factor} \times (\text{GST} + 1)) \times 35 \text{ days}$$

$$\text{PML} = (\text{Average daily load} \times \text{Average future expected spot price} \times \text{Participant Risk Adjustment Factor} \times \text{PM Volatility factor} \times (\text{GST} + 1)) \times 7 \text{ days}$$

The cost of funding a bank guarantee for the MCL associated with the single MWh is assumed to be a 2.5 percent annual charge for 42 days or  $2.5\% \times (42/365) = 0.288$  percent.

### ***Hedge prudential costs***

ACIL Allen relies on the futures market to determine hedging costs. The futures market includes prudential obligations by requiring entities to lodge initial margins (we assume cash) when contracts are purchased or sold. We understand that the cash that is lodged as an initial margin receives a money market related return which offsets some of the funding costs. The current money market rate is 0.10 per cent. Additional margin calls may apply where contracts move unfavourably for the purchaser or seller. However, as these may be favourable or unfavourable, we have assumed that they average out over time.

We understand that the initial margin is set based on three parameters being:

- the price scanning range (PSR) expressed as a percentage of the contract face value and is set for each of the base, peak and cap contract types
- the intra monthly spread charge and is set for each of the base, peak and cap contract types
- the spot isolation rate and is set for each of the base, peak and cap contract types.

Using the annual average futures price and applying the above factors gives an average initial margin for each quarter. This is divided by the average hours in the given quarter. Then applying an assumed funding cost but adjusted for an assumed return on cash lodged with the clearing results in the prudential cost per MWh for each contract type.

### **Reliability and Emergency Reserve Trader (RERT)**

Given the RERT is called upon under extreme circumstances only, ACIL Allen is of the opinion that it is difficult to project into the future. Although it may be possible to make use of previous costs of the RERT and relate these to AEMO’s projection of USE in the ES00, there is little data available at this point to take this approach.

Therefore, as with the ancillary services, we use the RERT costs as published by AEMO for the 12-month period prior to the Final Determination. ACIL Allen expresses the cost based on energy consumption, by taking the reported cost in dollar terms from AEMO for the given region and prorating the cost across all consumers in the region on a consumption basis.

## Retailer Reliability Obligation

The Retailer Reliability Obligation (RRO) started on 1 July 2019 to help manage the risk of declining reliability of supply in response to the recent large amounts of investment in intermittent renewable projects coupled with recent and potential closures of thermal power stations.

If the RRO is triggered for a given quarter and region of the NEM, then retailers need to secure sufficient *qualifying contracts* to cover their share of a one-in-two-year peak demand.

The RRO is currently not triggered for 2022-23, and hence we are not required to account for the RRO in the wholesale costs for 2022-23. However, it is worth noting that this cost component should be included as part of the wholesale cost if the RRO is triggered in future determinations.

We think that entering into a mix of firm base, peak, and cap contracts satisfies the qualifying contract definition. As part of the current WEC estimation methodology, an algorithm is run to determine the optimal hedge cover for a given distribution zone for each quarter of the given determination period.

The total optimal cover is expressed as a percentage of the P50 annual peak demand for the given quarter – which is analogous to a one-in-two-year peak demand referred to in the RRO.

Our proposed approach to account for the triggering of the RRO in the estimated WEC is:

- If the overall level of the optimal contract cover is less than 100 per cent of the P50 annual peak demand, then increase the overall level of contract cover to 100 per cent. This will result in an increase in the WEC value since the cost of the additional contracts will be included.
- If the overall level of the optimal contract cover is equal to or greater than 100 per cent of the P50 annual peak demand then no change is required, and hence the RRO has no impact on the WEC.

### 2.3.3 Environmental costs

---

#### Large-scale Renewable Energy Target (LRET)

By 31 March each compliance year, the Clean Energy Regulator (CER) publishes the Renewable Power Percentage (RPP), which translates the aggregate LRET target into the number of Large-scale Generation Certificates (LGCs) that liable entities must purchase and acquit under the scheme.

The RPP is determined ex-ante by the CER and represents the relevant year's LRET target (in fixed GWh terms) as a percentage of the estimated volume of liable electricity consumption throughout Australia in that year.

The estimated cost of compliance with the LRET scheme is derived by multiplying the RPP and the determined LGC price to establish the cost per MWh of liable energy supplied to customers. Since the cost is expressed as a cost per MWh, it is applicable across all retail electricity tariffs.

#### **Market-based approach**


A market-based approach is used to determine the price of a LGC, which assumes that an efficient and prudent electricity retailer builds up LGC coverage prior to each compliance year.

This approach involves estimating the average LGC price using LGC forward prices for the two relevant calendar compliance years in the determination period. Specifically, for each calendar compliance year, the trade-weighted average of LGC forward prices since they commenced trading is calculated.

To estimate the costs to retailers of complying with the LRET for 2022-23, ACIL Allen uses the following elements:

- The average of the trade-weighted average of LGC forward prices for 2022 and 2023 from brokers TFS
- the Renewable Power Percentages (RPPs) for 2022, published by the CER
- estimated RPP values for 2023<sup>3</sup>.

**Figure 2.4** Steps to estimate the cost of LRET



Source: ACIL Allen

### Small-scale Renewable Energy Scheme (SRES)

Similar to the LRET, by 31 March each compliance year, the CER publishes the binding Small-scale Technology Percentage (STP) for a year and non-binding STPs for the next two years.

The STP is determined ex-ante by the CER and represents the relevant year’s projected supply of Small-scale Technology Certificates (STCs) as a percentage of the estimated volume of liable electricity consumption throughout Australia in that year.

The estimated cost of compliance with the SRES is derived by multiplying the estimated STP value.


To estimate the costs to retailers of complying with the SRES, ACIL Allen uses the following elements:

- the binding Small-scale Technology Percentages (STPs) for 2022 to be published by the CER

<sup>3</sup> The estimated RPP value for 2023 is estimated using ACIL Allen’s estimate of liable acquisitions and the CER-published mandated LRET targets for 2023.

- an estimate of the STP value for 2023<sup>4</sup>
- CER clearing house price<sup>5</sup> for 2022 and 2023 for Small-scale Technology Certificates (STCs) of \$40/MWh.

**Figure 2.5** Steps to estimate the cost of SRES



Source: ACIL Allen

### 2.3.4 Energy losses

Some electricity is lost when it is transported over transmission and distribution networks to customers. As a result, retailers must purchase additional electricity to allow for these losses when supplying customers.

The components of the wholesale and environmental costs are expressed at the relevant regional reference node (RRN). Therefore, prices expressed at the regional reference node must be adjusted for losses in the transmission and distribution of electricity to customers – otherwise the wholesale and environmental costs are understated. The cost of network losses associated with wholesale and environmental costs is separate to network costs and are not included in network tariffs.

<sup>4</sup> The STP value for 2023 is estimated using estimates of STC creations and liable acquisitions in 2023, taking into consideration the CER's non-binding estimate.

<sup>5</sup> Although there is an active market for STCs, ACIL Allen is not compelled to use market prices. This is mainly because historical prices might not be the best indicators of future prices as the market is designed to clear every year – so in theory prices could be \$40 or at least very close to it. This assumes that the CER provides an accurate forecast of created certificates underpinning the STP for the next year.

Distribution Loss Factors (DLF) for each distribution zone and average Marginal Loss Factors (MLF) for transmission losses from the node to major supply points in the distribution networks are applied to the wholesale energy cost estimates to incorporate losses.

The loss factors used are published by AEMO one year in advance for all NEM regions. Average transmission losses by network area are estimated by allocating each transmission connection point to a network based on their location. Average distribution losses are already summarised by network area in the AEMO publication.

As described by AEMO<sup>6</sup>, to arrive at prices at the customer terminal (price at load connection point) the MLF and DLF are applied to the prices at the regional reference node (RRN) as follows:

$$\text{Price at load connection point} = \text{RRN Price} * (\text{MLF} * \text{DLF})$$

Given the timing of the Draft and Final Determinations tends to straddle AEMO's release dates of their MLFs and DLFs, the estimated losses for the Draft Determination are invariably equal to the losses from the previous year's Final Determination, and are then updated for the Final Determination upon release of AEMO's updated reports. Hence, the MLFs used to estimate losses for the Draft Determination for 2022-23 are set to equal the losses from the 2021-22 Final Determination.

---

<sup>6</sup> See Page 23 of the AEMO publication *Treatment of loss factors in the national electricity market- July 2012*

# Responses to submissions to Interim consultation paper

# 3

The QCA forwarded to ACIL Allen a total of seven submissions in response to its Interim consultation paper. ACIL Allen reviewed the submissions to identify issues that related to our methodology and required our consideration for the 2022-23 Draft Determination. A summary of the review is shown below in Table 3.1.

The issues raised in the submissions cover the following broad areas:

- ex-post assessment of the WEC
- availability of cap contracts
- price outcomes
- load shape
- estimating NEM fees.

**Table 3.1** Review of issues raised in submissions in response to the Interim consultation paper

ID	Stakeholder	Wholesale energy costs	Contract prices /hedge model	Renewable energy policy costs	NEM fees	Prudential costs	Energy losses
1	Bundaberg Regional Irrigators Group	Nil	Nil	Nil	Nil	Nil	Nil
2	CANEGROWERS	Yes	Nil	Nil	Nil	Nil	Nil
3	Cotton Australia	Nil	Nil	Nil	Nil	Nil	Nil
4	Ergon Energy Network and Energex	Nil	Nil	Nil	Nil	Nil	Nil
5	Ergon Energy Retail	Yes	Yes	Nil	Yes	Nil	Nil
6	Pioneer Valley Water Co-operative Limited	Nil	Nil	Nil	Nil	Nil	Nil
7	Queensland Farmers' Federation	Nil	Nil	Nil	Nil	Nil	Nil

Note: Yes = an issue was raised that required ACIL Allen's consideration

Source: ACIL Allen analysis of QCA supplied documents

## 3.1 Ex-post assessment of the WEC

CANEGROWERS on page three of its submission suggests an ex-post assessment be undertaken to assess:

*the energy costs Ergon incurs in its energy purchases in the previous regulatory period and compare with those allowed costs for that period.*

Setting aside confidentiality issues and the inability of reporting transparently any analysis of Ergon's actual costs, assessing the actual energy costs incurred by a retailer is not a trivial exercise. This would require access to Ergon's actual hedge book, and the ability to sensibly disentangle the components of the hedge book related to customers on notified prices by tariff type. The analysis would also require consideration to long-dated contracts that Ergon has in place. The intent of the WEC estimation methodology has been consistent – it is to adopt a simplified hedging strategy that relies on contemporaneous publicly available contract data as much as possible, rather than opaque and long-dated contracts or internal hedges. In any case, undertaking such an analysis would not allow for an assessment of the future energy costs for the following regulatory period.

Ergon Energy Retail also suggest consideration be given to an ex-post assessment on page nine and 11 of its submission with the intent of making further adjustments to the simulation modelling to account for additional price volatility:

*... Ergon Energy Retail has observed that Queensland spot prices are currently tracking well above the estimation of ACIL Allen for wholesale spot prices for the 2021/22 financial year (estimation completed as part of the 2021-22 pricing determination process). ACIL Allen's modelling had a range of \$40/MWh to \$70/MWh for the full year yet the average financial year to date Queensland spot price is \$88.74/MWh. This outcome is not surprising given that the ACIL Allen modelling was completed prior to the Callide Power Station incident in May 2021 which has been a significant factor (but not the only factor) in the on-going spot price volatility and surging forward market prices the market has seen this financial year.*

*The Callide Power Station event, along with other power station outages including the current Swanbank outage, demonstrate that unexpected and severe supply side events can occur and, with an aging power station fleet, the possibility of these events need to be factored into market modelling for the energy cost component of retail tariffs.*

...

*While other retailers are able to manage these financial repercussions and risks via changes in their retail prices (within the bounds of the DMO), as the QCA is aware, Ergon Energy Retail does not have this flexibility and must accept the WEC and the retail prices as determined by the QCA. Given this, we recommend the QCA update its scenario modelling to allow for supply side events, additional volatility and spread in the wholesale prices aligned with current market trends.*

In essence, the CANEGROWERS and Ergon submissions request the same thing – but for diametrically opposed reasons and intended outcomes.

The estimated WEC for any determination will invariably be different to the actual WEC incurred. This will be a function of several factors, including the actual hedging strategy adopted by a retailer (noting different retailers may have different strategies) compared with the simplified hedging strategy adopted in the methodology, the actual load profiles, spot price and contract price outcomes.

Although we attempt to minimise the error of the estimate by undertaking a large number of simulations to account for variations in weather related demand, thermal plant availability, renewable energy resource, and spot price outcomes, the methodology does not attempt to predict the final trade weighted average contract price for each of the assumed contract products adopted in the hedging strategy. Instead, the methodology relies on contract data available at the time the Determination is made.


Contract prices are a key driver of the WEC estimate. In some years, contract prices may increase after the Final Determination is made, in other years they may decrease, and in some cases, they may remain relatively stable. Figure 3.1 provides three examples of this phenomenon for quarter one base contracts in Queensland over the past three years. The graphs show the daily contract prices, the moving trade weighted average price, as well as the trade weighted average price at the time of the respective Final Determination.

After the date the 2019-20 Final Determination was made, Q1 2020 traded prices increased slightly and then decreased slightly resulting in an actual trade weighted average price very similar to that used in the Final Determination. This is an example of a stable market price environment (at least in terms of the trade weighted average price) – resulting in a reasonably close estimate.

After the date the 2020-21 Final Determination was made, Q1 2021 traded prices decreased consistently resulting in an actual trade weighted average price about \$8.50 lower than that used in the Final Determination. This is an example of a decreasing market price environment – resulting in an overestimate of the WEC (all other things equal).

After the date the 2021-22 Final Determination was made, Q1 2022 traded prices increased consistently resulting in an actual trade weighted average price about \$17.00 higher than that used in the Final Determination. This is an example of an increasing market price environment – resulting in an underestimate of the WEC (all other things equal).

**Figure 3.1** Daily settlement prices and trade volume weighted prices (\$/MWh) for Q1 base contracts in Queensland



Source: ACIL Allen analysis of ASX Energy data

The graphs in Figure 3.1 demonstrate a number of important points about the WEC estimation methodology:

- It is much easier to estimate the WEC during periods of contract price stability.


- It is much more challenging to estimate the WEC during periods of increasing or decreasing contract prices.
- The error in the WEC estimate, due to contract price variation, is likely to be greater in an environment of increasing prices, than it is in an environment of decreasing prices. This is because of the skewed nature of wholesale electricity prices in the NEM – prices can increase a lot more than they can decrease – and demonstrates the risk faced by retailers. This is part of the reason why we recommend adopting the 95<sup>th</sup> percentile of the simulated WECs.

In some years prices will increase, and in others they will decrease. It is unlikely that the market will enter into an extended period of seemingly ever-increasing or -decreasing prices – at some point, the market will respond accordingly with investment and/or retirement of capacity.

Hence, it is likely that over the long run, the market will follow some form of pattern of increasing, decreasing and stable price outcomes. With this in mind, the methodology may well result in a comparatively smooth WEC estimate trajectory – underestimating outcomes in an increasing price environment, and overestimating outcomes in a decreasing price environment – as illustrated in Figure 3.2.

On this basis, we are of the view that no change is required to the methodology.

**Figure 3.2** Illustrative comparison of WEC estimation accuracy given contract market environment



Source: ACIL Allen

### 3.2 Availability of cap contracts

Ergon Energy Retail on page 10 its submission suggests a lower degree of availability of cap contracts on ASX Energy should be a consideration in the methodology:

*There is low interest in quarterly caps as published by the ASX in Queensland due to the inherent risk to sellers in offering this product when spot prices are volatile. While this does not include over the counter (OTC) interest, ACIL Allen should not assume that retailers can hedge the majority of their exposure in the visible and liquid cap market.*


Ergon Energy Retail present a table showing the decline in open interest between 2022 and 2024 for quarterly cap products from ASX Energy.

ACIL Allen notes that the degree of open interest tabled in Ergon Energy Retail’s submission declines between 2022 and 2024. But that in itself is not unusual – open interest beyond the immediate 12-month period is invariably lower than the current period.

Figure 3.3 shows the actual cumulative trade volumes of quarterly cap products at the time of previous final determinations, compared with the volumes for this current Draft Determination. Setting aside 2021-22, when cap volumes were much lower due to the transition to 5MS, cumulative trade volumes to date for 2022-23 are on par or tracking close to trade volumes of most previous years. Further, the trade volumes for 2022-23 will increase between the Draft Determination and the Final Determination. On this basis, we see no reason to alter the methodology.

As noted in many of our reports for previous determinations, by using ASX Energy contract data, the methodology is not explicitly assuming that retailers only hedge with using ASX Energy products. Rather, the methodology develops a simplified hedging strategy using transparent ASX Energy data to represent the costs of hedging.

**Figure 3.3** Cumulative trade volumes of ASX Energy quarterly caps in Queensland



*Note: Volumes for 2022-23 are as at time of the Draft Determination, whereas as volumes for other years are taken about three months later, at the time of the Final Determination.*


*Source: ACIL Allen analysis of ASX Energy data*

### 3.3 Price shape

Ergon Energy Retail on page 10 its submission notes the continued increase in propensity for negative spot price events, and the changing shape of spot prices by time of day in Queensland, due to the reduction in spot price outcomes during daylight hours in response to the continued uptake of rooftop PV, and commissioning of utility scale PV.

The methodology takes into account the assumed uptake of rooftop PV, and commissioning of committed new utility scale PV, driving the change in price shape as shown in Figure 3.4. The modelling suggests further downward pressure on spot price outcomes during daylight hours compared with recent history, and an increase in negative or zero price outcomes. Across the 562 annual spot price simulations for 2022-23, the percentage of hourly price outcomes less than or equal to zero ranges between 11 and 15 per cent, compared with six per cent in 2021. On this basis, we think the methodology is appropriately capturing the change in price shape.

**Figure 3.4** Simulated average time of day spot price (\$/MWh, nominal) for Queensland for 2022-23 compared with range of actual annual outcomes in past five years



Source: ACIL Allen analysis, and AEMO data

### 3.4 Load shape

Ergon Energy Retail on page 11 of its submission make some general comments about load shape, including noting the use of the NSLP remains appropriate at this point in time. However, Ergon Energy Retail raises the issue of interval meter penetration and its impact on the future determinations in terms of load shape considerations.

In our view, this is a key issue to be considered in future determinations: whether using the NSLP remains valid when interval meter penetration breaches a particular threshold, or whether both the NSLP and interval meter data ought to be combined. At this stage, ACIL Allen has not been asked by the QCA to report WEC estimates using interval meter data. However, the methodology can be readily adapted to do so in the future.

### 3.5 NEM fees

Ergon Energy Retail on page 12 of its submission notes:

*... notes the oversight of the inclusion of the Australian Energy Market Operator (AEMO) fees levied on retailers for five-minute settlement (5MS) and for the DER integration program. Since 1 July 2021..., AEMO has been able to recover its costs associated with information technology upgrades and 5MS and Global Settlement compliance, and for the cost recovery of the DER integration program, as a separate fee on electricity retailers. These costs were not incorporated by the QCA in 2021-22 prices yet are a cost to the retail business. Consequently, Ergon Energy Retail is of the view that there is a need for an adjustment, through the cost pass-through mechanism, to recover the 2021-22 AEMO 5MS and DER fees...*

ACIL Allen estimates the NEM fees using AEMO’s latest available budget document. In the case of the 2021-22 Final Determination, we used AEMO’s *Electricity Final Budget & Fees 2020-21*, which is the same approach as used in the previous 2020-21 Determination. That is, we use the previous year’s NEM fees for the current determination year, which in effect means the NEM fees are lagged by a year.

Prior to the previous two years, AEMO included forecasts of NEM fees in its budget document beyond its current budget year, and we adopted the corresponding year’s forecast in earlier determinations. However, AEMO no longer publishes NEM fee forecasts beyond the current budget

year. Hence, for the past two determinations we have adopted the current NEM fees from the latest available budget document, which results in a 12-month lag.

For this current Draft Determination, we have used AEMO's *Electricity Final Budget & Fees 2021-22*, which includes fees related to 5MS IT system costs and DER integration.

Although this approach results in a 12-month lag, we note that NEM fees represent less than one per cent of the Total Energy Cost and are of the same order of magnitude as ancillary services costs which are also lagged by 12 months. Attempting to develop a methodology to forecast NEM fees is unlikely to result in a more accurate estimate. On this basis, we are of the view that no change is required to the methodology.

# Estimation of energy costs

# 4

## 4.1 Introduction

In this chapter we apply the methodology described in Chapter 2, and summarise the estimates of each component of the Total Energy Cost (TEC) for each of the NSLPs and CLPs for 2022-23.

### 4.1.1 Historic demand and energy price levels

Figure 4.1 shows the average time of day spot price for the Queensland region of the NEM, and the associated average time of day load profiles for the past 10 years. The graphs are useful in understanding the dynamics of the absolute and relative wholesale electricity price changes in the profiles.

It is worth noting the uplift in spot prices between 2014-15 and 2016-17, across most periods of the day. During this period, wholesale spot prices increased by about \$40/MWh in Queensland. This was a result of coal station closures (Wallerawang in New South Wales in 2014, Northern in South Australia in 2016, and Hazelwood in Victoria in 2017), an increase in the underlying demand in Queensland due to the ramping up of production associated with the LNG export facilities in Gladstone, as well as an increase in gas prices into gas fired generators across the NEM, and an increase export coal prices in New South Wales and Queensland, as well as coal supply constraints into coal fired power stations in New South Wales.

Prices in 2017-18 declined by about \$20/MWh compared with 2016-17 to about \$73/MWh (representing a decrease of just over 20 per cent). This decline was driven by a slight decrease in gas prices, the commissioning of just under 700 MW of solar and wind farms, the decline in coal costs in New South Wales coal fired power stations, and the return to service of Swanbank E.

Prices in 2018-19 increased by about \$8/MWh compared with 2017-18 to about \$80/MWh. This was largely driven by an increase in morning and evening peak prices due to an increase in gas prices, and an increase in prices at other times due to an increase in the export coal price (which affects New South Wales and some Queensland coal fired power stations), rather than an increase in price volatility.

Compared with 2018-19, wholesale spot prices in 2019-20 decreased by about \$25/MWh in Queensland. This was largely a result of the continued commissioning of large-scale renewable generation across the NEM, as well as a decline in gas prices due to a slightly better global supply outlook, which has meant LNG exporters have made more supply available to the domestic market due to depressed international prices. South-east Queensland temperature outcomes in January and February 2020 were comparatively milder than January and February 2019 – with temperature about equal to the long-term average. South-east Queensland rainfall over the same period in 2020 was above average, and in contrast to the dry summer of 2018-19.

In 2020-21, prices were generally lower than in 2019-20 up until the last six weeks of the financial year when Callide C unit 4 suffered a critical outage in May 2021 which resulted in multiple coal fired power station units tripping in Queensland. A consequence of this incident was an increase in price volatility due to lower levels of plant availability, which resulted in the annual wholesale spot price being by about \$10/MWh higher than that of 2019-20.

Prices in Queensland for 2021-22 to date have increased by about \$30/MWh when compared with 2020-21. This is despite the continued uptake of rooftop PV reducing price outcomes during daylight hours. The main reason for the increase in prices overall is the continued outage of Callide C Unit 4 (which is not expected to return until the end of 2022 at the earliest), an increase in export coal prices, and an increase in gas prices.


In relation to each profile, we note the following:

- The annual time of day price profile has been volatile over the past eight years – with the overall level and shape of the price profile changing from one year to the next. For example, in 2011-12 the time of day profile was very flat compared with 2014-15. In 2012-13 and 2013-14, prices increased largely because of the carbon tax. Between 2016-17 and 2018-19 price volatility has decreased – particularly during the evening peak periods. Prices have generally peaked in the afternoon and evening, whereas in some years there was also a morning peak.
- In 2021-22 to date, prices during daylight hours have decreased (due to further rooftop PV uptake), but these are more than offset by strong increases in prices during the evening peak and overnight (due to reduced plant availability, and increasing gas and coal prices). In short, the profile of prices varies from one year to the next – noting that these are the annual profiles (seasonal profiles are even more variable over time).
- The load profile of tariff 31 has been relatively consistent from one year to the next since 2011-12 – ramping up from about 9:30 pm, peaking at about midnight and then ramping down to about 3:00 am. This is inversely correlated with the price profile – with load higher at times of lower spot prices. This has resulted, on average, in a relatively low wholesale energy cost for tariff 31, compared with the other tariffs.
- The load profile of tariff 33 has been relatively consistent from one year to the next for most parts of the day. However, there was some volatility between 5:30 pm and 10:30 pm over the past few years. The load exhibits a morning peak at around 8:00 am – and prices also experience uplift around that time. The load also exhibits an evening peak at around 9:30 pm – but this varies from year to year (note that in 2014-15 and 2015-16 it tends to peak around 8:30 pm). Compared with tariff 31, the load profile of tariff 33 is weighted more towards the daylight hours and the evening peak, and hence it is not surprising that its wholesale energy costs are higher than those of tariff 31. That said, with a continued decrease in prices during daylight hours (due to continued rooftop PV uptake), costs of tariff 33 may well converge with those of tariff 31 over time.
- Over the past seven or so years, the Energex NSLP and the Ergon NSLP load profiles, have experienced a carving out of load during daylight hours with the increased penetration of rooftop solar PV. This results in the load profile becoming peakier over time and consequently, the demand weighted spot prices<sup>7</sup> (DWP) for the NSLP load profiles have increased relative to the corresponding regional time weighted average spot price (TWP). The carving out of the NSLPs during daylight hours increases the relative weighting of the load profile during the higher priced evening peak and reduces the relative weighting during the lower priced daylight hours.

<sup>7</sup> The demand weighted price is in effect the unhedged wholesale energy cost that the retailers pay AEMO for the NSLP.

- However, over the past few years the rate of carve out has slowed and this is most likely due to new rooftop solar PV installations being paired with the installation of interval meters – removing those consumers from the NSLP.
- The Energex NSLP load profile has a higher weighting towards the peak periods – particularly the evening peak and hence it is not surprising that the NSLP has the highest wholesale energy cost out of the two NSLP profiles.
- Although the increased penetration of rooftop PV is placing downward pressure wholesale spot prices during daylight hours, price volatility during the evening peak has persisted. Indeed, it has increased in 2021-22 to date due to increased gas prices and the outage at Callide C.

**Figure 4.1** Actual average time of day wholesale electricity spot price (\$/MWh, nominal) and load profiles (MW, relative) – Queensland – 2011-12 to 2020-21




Note: The term relative MW means the loads for each tariff and year have been scaled so they sum to one. This removes differences in absolute scale between the different tariffs and changes in absolute size over time. This is an appropriate representation of the loads since it is the relative shape of the load profile, not its absolute size, which determines its wholesale energy cost.

Source: ACIL Allen analysis of AEMO data

Figure 4.2 shows the actual annual demand weighted spot price (DWP) for each of the tariff loads compared with the time weighted average spot price in Queensland (TWP) over the past 12 years. As expected, the DWPs for tariffs 31 and 33 are below the DWP for the NSLPs in each year, with tariff 31 having the lowest price. Although the rank order in prices by tariff has been consistent in each year, the dollar value differences between the prices has varied from one year to the next. For example, in 2011-12, 2017-18, and 2018-19, the relatively flatter half-hourly price profile resulted in the profiles having relatively similar wholesale spot prices. However, from 2014-15 and 2016-17, the increased price volatility across the afternoon period has resulted in the NSLP spot price diverging away from tariff 31 and 33. Conversely, the increase in off-peak spot prices in 2015-16 lifted the DWP of tariff 31 and 33 up towards that of the NSLP.

It is also worth noting that it has only been for four of the past 12 years that the control loads have noticeably lower DWPs when compared with the NSLPs. Certainly in 2017-18 the DWPs across all tariff classes were comparatively very similar. ACIL Allen raises this point as it is often questioned/noted in submissions that the wholesale energy costs for the control loads produced by our methodology are no longer substantially lower than those of the NSLPs. The control loads are subject to the DNSPs in that they are used to manage network congestion – hence their shape is not purely a result of consumer behaviour.

**Figure 4.2** Actual annual average demand weighted price (\$/MWh, nominal) by profile and Queensland time weighted average price (\$/MWh, nominal) – 2009-10 to 2020-21



Note: Values reported are spot (or uncontracted) prices.

Source: ACIL Allen analysis of AEMO data

The volatility of spot prices (timing and incidence) provides the incentive to a retailer to hedge their load, since hedging of the loads reduces a retailer’s exposure to the volatility. The suite of contracts (as defined by base/peak, swap/cap and quarter) used in the methodology does not change from one year to the next. However, the movement in contract price is the key contributor to movement in the estimated wholesale energy costs of the different profiles year on year, as is shown in Figure 4.3.

Compared with 2021-22, futures base and peak contract prices for 2022-23, on an annualised and trade weighted basis to date, have increased by about \$7.30/MWh and \$28.50/MWh respectively for Queensland. Cap contract prices have increased by about \$6.20/MWh.


Unlike the previous four determinations in which there was a clear decline in contract prices, the market is now expecting an increase in price outcomes as the amount of utility scale renewable investment coming on-line slows between 2021-22 and 2022-23 (compared with recent years), coupled with the continued unavailability of Callide C Unit 4 for at least half of 2022-23, and stronger coal and gas prices, and the closure of Liddell in New South Wales.

Further, cap contract prices have increased substantially for 2022-23 compared with 2021-22. This may reflect a degree of uncertainty faced by providers of caps around the ability of their peaking plant to cover price spikes in the spot market under five-minute settlement (5MS), as well as an expectation of an increase in underlying price volatility. A \$1/MWh increase in cap price can increase the WEC for a NSLP by about \$3/MWh, all other things equal, due to the peaky shape of the NSLP.

The cost of hedging the NSLP is further exacerbated by the expected continued strong uptake of rooftop PV which carves out the demand during daylight hours, resulting in very low spot price outcomes during daylight hours, certainly less than the base contract price, making the already peaky NSLP demand profile more expensive to hedge.

The increase in contract prices means that the trade weighted average price levels to date for 2022-23 are quite similar to those of 2019-20. The decline in prices experienced since 2017-18 appears to have come to an end at this point in time.

**Figure 4.3** Queensland Base, Peak, and Cap trade weighted average contract prices (\$/MWh, nominal) – 2013-14 to 2022-23



Source: ACIL Allen analysis of ASX Energy Data

## 4.2 Estimation of the Wholesale Energy Cost

### 4.2.1 Estimating contract prices

Contract prices were estimated using the trade-weighted average of ASX Energy daily settlement prices since the contract was listed up until 21 January 2022 inclusive.

Table 4.1 shows the estimated quarterly swap and cap contract prices for 2021-22 and 2022-23. Contract prices have increased from 2021-22 to 2022-23 for all products and quarters. However, there are very strong increases in cap prices across all quarters.

This combination of increasing base prices, coupled with strong increasing peak and cap prices suggests the market is expecting a further decline in spot prices across daylight hours which is offset by increase in spot prices during evening and possibly morning peak.

**Table 4.1** Estimated contract prices (\$/MWh, nominal) - Queensland


	Q3	Q4	Q1	Q2
2021-22				
Base	\$42.03	\$43.92	\$60.50	\$40.68
Peak	\$55.38	\$55.21	\$76.75	\$45.00
Cap	\$2.18	\$5.73	\$13.99	\$3.30
2022-23				
Base	\$51.72	\$53.80	\$66.23	\$46.15
Peak	\$62.00	\$65.40	\$134.00	\$82.68
Cap	\$5.89	\$9.33	\$25.57	\$6.61
Percentage change from 2021-22 to 2022-23				
Base	23%	22%	9%	13%
Peak	12%	18%	75%	84%
Cap	170%	63%	83%	100%

Source: ACIL Allen analysis using ASX Energy and TFS data up to 21 January 2022 for 2022-23

In addition to the increase in rooftop PV, another driver of change in the relativity of base and cap contract prices in 2022-23 is an increase in gas prices for gas fired generation. Spot prices across the east coast gas market have increased from their lower levels observed over the previous few years to about \$10/GJ - a reflection of higher international LNG prices which affects domestic gas prices via a higher LNG netback price.


The following charts show daily settlement prices and trade volumes for 2022-23 ASX Energy quarterly base futures, peak futures and cap contracts up to 21 January 2022. It can be seen that the trading of these contracts tends to commence from mid to late 2019.

**Figure 4.4** Time series of trade volume and price – ASX Energy base futures - Queensland




Source: ASX Energy data up to 21 January 2022

Figure 4.5 Time series of trade volume and price – ASX Energy peak futures - Queensland



Source: ASX Energy data up to 21 January 2022

Figure 4.6 Time series of trade volume and price – ASX Energy \$300 cap futures - Queensland




Source: ASX Energy data up to 21 January 2022

#### 4.2.2 Estimating wholesale spot prices

ACIL Allen’s proprietary electricity model, *PowerMark* was run to estimate the hourly spot prices for the 561 simulations (51 demand and 11 outage sets).

Figure 4.7 shows the range of the upper one percent segment of the demand duration curves for the 51 simulated Queensland system demand sets resulting from the methodology for 2022-23, along with the range in historical demands since 2011-12. The simulated demand sets represent the upper, lower, and middle of the range of demand duration curves across all 51 simulated sets. It can be seen that the demand duration curves of the simulated demand sets for 2022-23 have a variation similar to that observed over the past five years - that is, the variation between the simulated demand sets does not just occur at the single peak annual demand but across a reasonable portion of the demands within the given simulation. This variation in demand contributes to the variation in modelled spot price outcomes as discussed further in this section.

**Figure 4.7** Comparison of upper one per cent of hourly loads of 2022-23 simulated hourly demand sets with historical outcomes – Queensland



Source: ACIL Allen analysis and AEMO data


We do not expect the simulated demand sets to line up perfectly with the historical demand sets, in terms of their absolute location. For example, the simulated demand sets for 2022-23 are generally higher than the pre-2016-17 observed demand outcomes in Queensland due to the step increase in demand due to the in-field compression associated with the LNG export projects in Gladstone. What is important, is that the range in simulated outcomes reflects the range experienced in the past, indicating that the methodology is accounting for an appropriate degree of uncertainty.

The left panel of Figure 4.8 shows the range of the simulated NSLP peak demands envelope recent actual outcomes. This variation results in the annual load factor<sup>8</sup> of the 2022-23 simulated demand sets ranging between 28 percent and 36 percent compared with a range of 29 percent to 43 percent for the actual Energex NSLP (as shown in the right panel of Figure 4.8). There has been an observable fall in the load factor in the actual NSLP in recent years due to an increase in penetration of rooftop solar PV panels. However, it is fair to say this reduction has slowed in the past couple of years – which may well be related to recent rooftop PV installations being associated with meter upgrades (from accumulation to interval meters) or changes in demand patterns due to COVID-19 restrictions.

All other things being equal, the increased peakiness of the load, which is hedged under the methodology, is likely to result in a larger degree of over hedging across the general day-time peak periods, resulting in a larger degree of over hedging overall on an annual basis, which means estimated hedging costs will increase.

<sup>8</sup> The load factor is a measure of the peakiness in the half hourly load profile across a given period of time. The annual load factor is the average of the half hourly loads for the given year divided by the maximum of the half hourly loads for that same given year.

**Figure 4.8** Comparison of upper one per cent of hourly loads and load factors of 2022-23 simulated hourly demand sets with historical outcomes – Energex NSLP



Source: ACIL Allen analysis and AEMO data

The chart in the upper left panel of Figure 4.9 compares the modelled annual regional TWP for the 561 simulations for 2022-23 with the regional TWPs from the past 21 years. Although there have been changes to both the supply and demand side of the market, the graph clearly shows that the simulations cover a wide range in potential spot price outcomes for 2022-23 when compared with the past 21 years of history.

Comparing the upper one percent of hourly prices from the simulations with historical spot prices (the upper right panel in Figure 4.9) shows the spread of the hourly prices from the simulations also more than adequately covers the historical spread of spot prices. It is also notable, that as would be expected, the distribution of simulated price outcomes demonstrates a strong positive skewness.

ACIL Allen is satisfied that PowerMark has performed adequately in capturing the extent and level of high price events based on the demand and outage inputs for the 561 simulations. The range in annual average contribution to the TWP, of hourly prices above \$300/MWh (shown in the mid left panel of Figure 4.9) for the 561 simulations is consistent with those recorded in history. For some of the 2022-23 simulations the contribution of price spikes is greater than historical levels, reflecting the continued outage of Callide C Unit 4, and the general tightening of the demand-supply balance in the market.


The mid right panel of Figure 4.9 compares the lower 50 per cent of hourly prices in the simulations with historical spot prices. The projected increase in uptake of rooftop PV coupled with the commissioning of the committed utility scale solar projects in Queensland by 2022-23 results in an increase in the proportion of hours in which the price is negative.

The lower left panel of Figure 4.9 compares the annual average time of day prices in the simulations with historical time of day spot prices. The continued increase in rooftop PV penetration and development of utility scale solar is projected to reduce price outcomes in 2022-23 during daylight hours.

Simulated spot prices during daylight hours for 2022-23 are on average around \$20/MWh – well below the annualised base contract price of about \$54/MWh (as shown in the lower right panel of Figure 4.9). Indeed, simulated prices during daylight hours are well below prices between 1am and 4am (historically the period of lowest price outcomes prior to the development of utility scale solar). During these periods, retailers will be making hedge difference payments.

Based on these metrics, ACIL Allen is satisfied that in an aggregate sense the distribution of the 561 simulations for 2022-23 cover an adequately wide range of possible annual spot price outcomes.

**Figure 4.9** Comparison of various metrics of hourly prices from the 2022-23 simulations with historical outcomes – Queensland



Source: ACIL Allen analysis and AEMO data


The maximum demand of the NSLP is not in isolation a critical feature in determining the cost of supply. The shape and volatility of the NSLP demand trace and its relationship to the shape and volatility of the regional demand/price traces is a critical factor in the cost of supplying the NSLP demand.

A test of the appropriateness of the simulated NSLP demand shape and its relationship with the regional demand shape can be undertaken by comparing the annual demand weighted price (DWP) for the NSLP with the corresponding regional TWP. Figure 4.10 shows that, for the past 11

financial years, the DWP for the Energex NSLP as a percentage premium over the Queensland TWP has varied from a low of 8 percent in 2011-12 and 2017-18 to a high of 54 percent in 2014-15. In the 561 simulations for 2022-23 for the NSLP, this percentage varies from 21 percent to 102 percent. The modelling suggests a greater range in the premium for 2022-23 as a result of greater variability in thermal power station availability and the increasing influence of variability in renewable energy resource availability coupled a decline in price outcomes during daylight hours when the NSLP demand is at its lowest.

The comparison with actual outcomes over the past 11 years in Figure 4.10 demonstrates that the relationship between the NSLP demand and corresponding regional spot prices in the 561 simulations is sound.

**Figure 4.10** Simulated annual DWP for Energex NSLP as percentage premium of annual TWP for 2022-23 compared with range of actual outcomes in past years



Source: ACIL Allen analysis and AEMO data

ACIL Allen is satisfied the modelled regional wholesale spot prices from the 561 simulations cover the range of expected price outcomes for 2022-23 across all three regions in terms of annual averages and distributions. These comparisons clearly show that the 51 simulated demand and renewable energy resource traces combined with the 11 thermal power plant outage scenarios provide a sound basis for modelling the expected future range in spot market outcomes for 2022-23.

#### 4.2.3 Applying the hedge model

The hedging methodology uses a simple hedge book approach based on standard quarterly base and peak swaps, and cap contracts. The prices for these hedging instruments are taken from the estimates provided in Section 4.2.1.

Contract volumes adopted for the hedging strategy for 2022-23 are calculated for each settlement class for each quarter as follows, and are largely similar (in percentage terms) from the 2021-22 determination:

Contract volumes are calculated for the tariff classes for each quarter as follows:

- The base contract volume is set to equal the 70th percentile of the off-peak period hourly demands across all 51 demand sets for the quarter. This is a slight increase compared with 2021-22 reflecting the changing differential between base and cap contract prices.
- The peak period contract volume is set to equal the 60th percentile of the peak period hourly demands across all 51 demand sets minus the base contract volumes for the quarter.
- The cap contract volume is set at 100 per cent of the median of the annual peak demands across the 51 demand sets minus the base and peak contract volumes.

However, given the Energex small business primary load control tariff, is a primary tariff, the optimal contract volumes are calculated separately, and are:


- The base contract volume is set to equal the 30th percentile of the off-peak period hourly demands across all 51 demand sets for the quarter.
- The optimal hedging strategy does not require peak contracts. This is likely due to the shape of the load profile which has relatively lower demand during daylight hours, and peaks later in the evening compared with the NSLPs.
- The cap contract volume is set at 70 per cent of the median of the annual peak demands across the 51 demand sets minus the base and peak contract volumes.

The same hourly hedge volumes (in MW terms) apply to each of the 51 demand sets for a given tariff class and year, and hence to each of the 561 simulations. To be clear, we are not altering the hedge volume (in MW terms) on an ex-post basis for each of the 51 demand sets. Therefore, the approach we use results in a hedging strategy that does not rely on perfect foresight but relies on an expectation of the distribution of hourly demands across a range of weather-related outcomes.

Once established, these contract volumes are then fixed across all 561 simulations when calculating the wholesale energy cost. The contract volumes for the Energex NSLP used are shown in Figure 4.11.

Generally, the contracting strategy places little reliance on peak contracts. This is not surprising – the carve out of demand during daylight hours (which makes up a reasonable part of the peak hours on business days), and the corresponding low spot prices during those hours makes the peak contracts generally unappealing. It is during these periods that the load will be over contracted and hence in effect retailers will be selling back to the market the extent of this over contracted position at the much lower spot prices. Further, the strategy's very low reliance on peak contracts matches well with the very small volume of peak contracts traded relative to base contracts in the actual futures market.


Figure 4.11 Contract volumes used in hedge modelling of 561 simulations for 2022-23 for Energex NSLP



Source: ACIL Allen analysis

Figure 4.12 shows that, by using the above contracting strategies, the variation in the annual hedged price for the NSLP is far less than the variation if the NSLP was to be supplied without any hedging and relied solely on spot price outcomes.

**Figure 4.12** Annual hedged price and DWP (\$/MWh, nominal) for Energex NSLP for the 561 simulations – 2022-23



Source: ACIL Allen analysis

#### 4.2.4 Summary of estimated Wholesale Energy Cost

After applying the hedge model, the final WEC estimate is taken as the 95th percentile of the distribution containing 561 WECs (the annual hedged prices). ACIL Allen’s estimate of the WEC for each tariff class for 2022-23 are shown in Table 4.2.

**Table 4.2** Estimated WEC (\$/MWh, nominal) for 2022-23 at the regional reference node

Settlement class	2021-22 – Final Determination	2022-23 – Draft Determination	Change from 2021-22 to 2022-23 (%)
Energex - NSLP - residential and small business	\$67.76	\$86.74	28%
Energex - Controlled load tariff 9000 (31)	\$53.34	\$66.29	24%
Energex - Controlled load tariff 9100 (33)	\$54.83	\$70.66	29%
Energex - NSLP - unmetered supply	\$67.76	\$86.74	28%
Ergon Energy - NSLP - CAC and ICC	\$61.09	\$77.43	27%
Ergon Energy - NSLP - SAC demand and street lighting	\$61.09	\$77.43	27%
Energex – Small business primary load control tariff	\$58.75	\$70.20	19%
Ergon – Large business primary and secondary load control tariffs	\$54.83	\$70.66	29%

Source: ACIL Allen analysis


The 2022-23 WECs for the NSLPs and CLPs increase by between 19 and 29 per cent compared with 2021-22 – reflecting the increase in base contract prices, the strong increase in cap contract prices and the decline in spot prices during daylight hours when demand is at its lowest point and hence over contracted.

As discussed earlier, the WEC for each tariff class is unlikely to decrease (or increase for that matter) by the same amount between determinations – whether in dollar or percentage terms – due to their different load shapes and differences in how the load shapes are changing over time.

Figure 4.13 shows the trend in WEC over the past determinations. The increase in the NSLP WECs between 2021-22 and 2022-23 represents the first increase since 2017-18, after four

consecutive years if decreasing WECs. Despite the increase in WECs in 2022-23, they are similar to the WEC levels of 2019-20, and are less than the WECs estimated for 2017-18 and 2018-19.

**Figure 4.13** Estimated WEC (\$/MWh, nominal) for 2022-23 at the regional reference node in comparison with WECs from previous determinations



Source: ACIL Allen analysis

#### 4.2.5 Comparison of WECs from previous determinations with actual spot market outcomes

---

Given the same WEC methodology has been adopted for the past nine determinations, there is now a reasonable time series of consistent data points to be able to make meaningful comparisons between actual outcomes in the market and the estimated WECs.


The main graph in Figure 4.14 compares actual spot market outcomes from the past nine years with the corresponding final determination trade volume weighted base contract prices and Energex NSLP WECs. The smaller graphs in Figure 4.14 provide pairwise comparisons of the different variables from the main graph. We have also included the WEC and contract price for this Draft Determination for completeness.

The key observations are:

- 1 In terms of the spot market, the Energex DWP (which is what retailers are charged by AEMO for the NSLP load) follows the movements in the Queensland TWP, albeit at a premium. This premium changes from year to year depending on the dynamics in the market at the time, and is influenced by the changing shape of the NSLP and spot price outcomes.
- 2 Trade weighted base contract prices tend to lag the trend in the TWP. This is because the trades for a given year that occur ahead of that year are partly influenced by what is happening in the market at the time the trade is made. For example, trades for 2019-20 that occurred prior to 2019-20 would have been partly influenced by the higher spot market outcomes in 2017-8 and 2018-19, resulting in a trade weighted average higher than the actual spot market outcome for 2019-20.
- 2 Further, the trend in contract prices is not quite as volatile as that of the spot market prices. This is because the contract price represents the average of market participants' views on the risk weighted outcome for the given year.
- 3 The WEC follows the trend in base contract prices. This is not surprising given the hedging strategy adopted to estimate the WEC makes use of those contract prices. The WEC also follows the trend in cap contract prices but these are not included given the difference in scale.
- 3 Although the WEC follows the trend in base contract prices, it does so at a reasonable premium. This is not surprising given the shape of the NSLP.
- 4 The lag in contract prices, relative to spot market outcomes, means that the WEC also lags actual spot market DWP for the NSLP. Given the trend in contract prices is not quite as volatile as that of the spot market prices, the trend in WEC is also not as volatile as the trend in the actual spot market DWP.
- 4 Across the entire time series, the average of the WECs is within \$2/MWh of the average of the actual spot market DWPs. This reflects the fact that on average, market participants, when entering into contracts, have an expectation that is not dissimilar to actual outcomes over the medium term.
- 4 The lag in WEC relative to the actual spot market DWP means that if one was to look at a snapshot or portion of the time series, then erroneous conclusions will be made. This is particularly the case for periods of consistently increasing or consistently decreasing price outcomes. For example, if the graph was truncated to include 2013-14 to 2016-17 only, then one might conclude that the WEC methodology results in estimates that are consistently lower than actual outcomes. Conversely, if the graph was truncated to include 2017-18 to 2020-21 only, then one might conclude that the WEC methodology results in estimates that are consistently higher than actual outcomes.

Although the WEC estimation methodology is a simplification of how retailers manage their retail load and exposure to the spot market, based on the above comparative analysis, ACIL Allen is satisfied that the methodology provides an unbiased estimate of the WEC.

**Figure 4.14** Comparison of time weighted spot prices, base contract prices, demand weighted spot prices, WECs (\$/MWh, nominal) – Energex NSLP



Note: WEC and base contract values for 2013-14 to 2021-22 are from the corresponding final determinations; WEC and base contract values for 2022-23 are from this current Draft Determination. TWP for 2021-22 is up to 21 January 2022. Energex NSLP data for 2021-22 is yet to be published by AEMO.

Source: ACIL Allen

### 4.3 Estimation of renewable energy policy costs

#### Renewable energy scheme (RET)

The RET scheme consists of two elements – the Large-scale Renewable Energy Target (LRET) and the Small-scale Renewable Energy Scheme (SRES). Liable parties (i.e. all electricity retailers<sup>9</sup>) are required to comply and surrender certificates for both LRET and SRES.

Energy costs associated with the LRET and the SRES have been estimated using price information from brokers TFS, information published by the Clean Energy Regulator (CER) and modelling by ACIL Allen. For the Draft Determination, ACIL Allen assesses the most up to date information available including ‘non-binding’ scheme parameters from the CER, and this information will be revised for the Final Determination when the CER has published the final binding parameters

Retailer compliance with these schemes operates on a calendar year basis and hence estimates are required 2022 and 2023 calendar years, with the costs averaged to estimate the 2022-23 financial year costs.

To estimate the costs to retailers of complying with both the LRET and SRES, ACIL Allen uses the following elements:

- historical Large-scale Generation Certificate (LGC) market forward prices for 2022 and 2023 from brokers TFS
- estimated Renewable Power Percentages (RPP) values for 2022 and 2023 of 18.54 per cent<sup>10</sup>
- non-binding Small-scale Technology Percentage (STP) values for 2022 and 2023 of 22.40 and 21.15 per cent respectively, as published by CER<sup>11</sup>
- CER clearing house price<sup>12</sup> for 2022 and 2023 for Small-scale Technology Certificates (STCs) of \$40/MWh.

The STPs for 2022 and 2023 used in the Draft Determination are the non-binding values published by the CER. Based on our interpretation of the three consultant reports published by the CER estimating the rooftop PV uptake<sup>13</sup> (an input in calculating the STPs), it appears the projected uptake rates for 2022 and 2023 are similar to recently observed uptake rates. However, the STPs also take into account the diminishing deeming period, which in net terms results in lower STPs when compared with the 2021-22 Final Determination. As we approach the end of the SRES (2030), unless there is a reasonable increase in the installation rate of rooftop PV systems, it is likely that the diminishing deeming period will more than offset an increase in uptake rate when calculating the STP in future years.

<sup>9</sup> Emissions Intensive Trade Exposed (EITE) industries such as aluminium are wholly or partially exempted and receive Partial Exemption Certificates (PEC) to be surrendered to the named liable entity.

<sup>10</sup> The RPP values for 2022 and 2023 are based on the CER’s published RPP for 2021, and assumes no change in liable acquisitions and the CER-published mandated LRET targets for 2022 and 2023. Any subsequent updates published by the CER will be included in the Final Determination.

<sup>11</sup> Any subsequent updates published by the CER will be included in the Final Determination.

<sup>12</sup> Although there is an active market for STCs, ACIL Allen is not compelled to use market prices. This is mainly because historical prices might not be the best indicators of future prices as the market is designed to clear every year – so in theory prices could be \$40 or at least very close to it. This assumes that the CER provides an accurate forecast of created certificates underpinning the STP for the next year.

<sup>13</sup> <http://www.cleanenergyregulator.gov.au/RET/Scheme-participants-and-industry/the-small-scale-technology-percentage/small-scale-technology-percentage-modelling-reports>

4.3.1 LRET

To translate the aggregate LRET target for any given year into a mechanism such that liable entities under the scheme may determine how many LGCs they must purchase and acquit, the LRET legislation requires the CER to publish the RPP by 31 March within the compliance year.


The RPP is determined ex-ante by the CER and represents the relevant year’s LRET target (in fixed GWh terms) as a percentage of the estimated volume of liable electricity consumption throughout Australia in that year.

The estimated cost of compliance with the LRET scheme is derived by applying the RPP to the determined LGC price to establish the cost per MWh of liable energy supplied to customers. Since the cost is expressed as a cost per MWh, it is applicable across all retail tariffs.

ACIL Allen has estimated the average LGC price using LGC forward prices provided by broker TFS.

The LGC price used in assessing the cost of the scheme for 2022-23 is found by taking the trade-weighted average of the forward prices for the 2022 and 2023 calendar years, respectively, since the contracts commenced trading. This is typically about 2.5 years prior to the commencement of the compliance year (see Figure 4.15). The average LGC prices calculated from the TFS data are \$26.54/MWh for 2022 and \$22.36/MWh for 2023.

Figure 4.15 LGC prices for 2022 and 2023 for 2022-23 (\$/LGC, nominal)



Source: ACIL Allen analysis of TFS data

The RPP value for 2021 was set by the CER on 1 April 2021 at 18.54 per cent. The RPP values for 2022 and 2023 is estimated by using the mandated target for 2022 and 2023 of 33 TWh and the CER’s published cumulative adjustment and estimate of electricity acquisitions in 2021 of 175.9 TWh. In other words, ACIL Allen has assumed electricity acquisitions remain constant in 2022 and 2023, and hence the RPP values for 2022 and 2023 are also 18.54 per cent.

Key elements of the 2022 and 2023 RPP estimation are shown in Table 4.3.

Table 4.3 Estimating the 2022 and 2023 RPP values

	2022	2023
LRET target, MWh (CER)	32,616,792	32,616,792
Relevant acquisitions minus exemptions, MWh (CER)	175,900,000	175,900,000
Estimated RPP	18.54%	18.54%

Source: ACIL Allen analysis of CER and AEMO data

ACIL Allen calculates the cost of complying with the LRET in 2022 and 2023 by multiplying the RPP values for 2022 and 2023 by the trade volume weighted average LGC prices for 2022 and 2023, respectively. The cost of complying with the LRET in 2022-23 was found by averaging the calendar estimates.

Therefore, ACIL Allen estimates the cost of complying with the LRET scheme to be \$4.53/MWh in 2022-23 as shown in Table 4.4.

**Table 4.4** Estimated cost of LRET – 2022-23

	2022	2023	Cost of LRET 2022-23
RPP %	18.54%	18.54%	
Trade weighted average LGC price (\$/LGC, nominal)	\$26.54	\$22.36	
<b>Cost of LRET (\$/MWh, nominal)</b>	<b>\$4.92</b>	<b>\$4.15</b>	<b>\$4.53</b>

*Source: ACIL Allen analysis of CER and TFS data*

#### 4.3.2 SRES

The cost of the SRES is calculated by applying the estimated STP value to the STC price in each compliance (calendar year). The average of these calendar year costs is then used to obtain the estimated costs for 2022-23.

ACIL Allen estimates the cost of complying with SRES to be \$8.71/MWh in 2022-23 as set out in Table 4.5.

**Table 4.5** Estimated cost of SRES – 2022-23

	2022	2023	Cost of SRES 2022-23
STP %	22.40%	21.15%	
STC clearing house price (\$/STC, nominal)	\$40.00	\$40.00	
<b>Cost of SRES (\$/MWh, nominal)</b>	<b>\$8.96</b>	<b>\$8.46</b>	<b>\$8.71</b>

*Source: ACIL Allen analysis of CER data*

#### 4.3.3 Summary of estimated LRET and SRES costs

Adding these component costs gives a total cost requirement for 2022-23 as set out in Table 4.6.

Since the 2021-22 estimate, the cost of LRET has increased by around six per cent, driven by higher LGC prices in 2022-23, and the cost of SRES has decreased by 24 per cent, driven by the shortening of the SRES deeming period.

**Table 4.6** Total renewable energy policy costs (\$/MWh, nominal) – 2022-23

	2021-22	2022-23
LRET	\$4.29	\$4.53
SRES	\$11.52	\$8.71
<b>Total</b>	<b>\$15.81</b>	<b>\$13.24</b>

*Source: ACIL Allen analysis*

## 4.4 Estimation of other energy costs

The estimates of other energy costs for the Draft Determination provided in this section consist of:

- market fees and charges including:
  - NEM management fees
  - Ancillary services costs
- spot and hedging prudential costs
- the Reliability and Emergency Reserve Trader (RERT).

### 4.4.1 NEM management fees

NEM management fees are payable by retailers to AEMO to cover operational expenditure, costs associated with full retail contestability (FRC), and the Energy Consumers Australia (ECA)<sup>14</sup>, DER and IT system upgrades for 5MS.

Based on projected fees in AEMO's *Electricity Final Budget & Fees 2021-22* our estimate of the fees for 2022-23 are \$0.67/MWh (up from \$0.49/MWh for 2021-22 in DMO 3). The breakdown of total fees is shown in Table 4.7. The majority of the increase in fees relates to the inclusion of IT upgrade costs for 5MS.

**Table 4.7** NEM management fees (\$/MWh, nominal) – 2022-23

Cost category	2021-22	2022-23
NEM fees (admin, registration, etc.)	\$0.37	\$0.40
FRC - electricity	\$0.078	\$0.081
ECA - electricity	\$0.040	\$0.040
DER fee	\$0.000	\$0.026
IT upgrade and 5MS/GS compliance	\$0.00	\$0.123
<b>Total NEM management fees</b>	<b>\$0.49</b>	<b>\$0.67</b>

Source: ACIL Allen analysis of AEMO reports

### 4.4.2 Ancillary services

AEMO provides weekly aggregated settlements data for ancillary service payments in each interconnected region. Using the average costs in each region over the preceding 52 weeks of currently available NEM ancillary services data as a basis for 2022-23, the estimates cost of ancillary services is shown in Table 4.8.

There has been a noticeable increase in weekly ancillary service costs in Queensland over the past two quarters as a result of upgrade works associated with the QNI giving rise to price separation between the two regions.

**Table 4.8** Ancillary services (\$/MWh, nominal) – 2022-23

Region	2021-22	2022-23
Queensland	\$0.41	\$1.26

Source: ACIL Allen analysis of AEMO data

<sup>14</sup> ECA requirements are measured in terms of connection points for small customers. It is not clear in AEMO's *Electricity Final Budget and Fees 2021-22* of the assumed number of connection points for small customers used in the estimate, therefore ACIL Allen has used DNSP customer numbers to estimate the cost of ECA requirements in \$/MWh terms.

### 4.4.3 Prudential costs

---

Prudential costs have been calculated for each jurisdiction NSLP. The prudential costs for the NSLP are then used as a proxy for prudential costs for the controlled load profiles in the relevant jurisdiction.

#### AEMO prudential costs

AEMO calculates a maximum credit limit for each counterparty in order to determine the requirement for any or a combination of:

- bank guarantees
- reallocation certificates
- prepayment of cash.

There is no fundamental requirement to reallocate prudential obligations – it is a retailer’s choice to do so. Assuming no reallocation and no vertical integration (either owned generation or PPAs), a retailer is required to provide suitable guarantees to the AEMO assessed maximum credit limit (MCL) which is calculated as follows:

$$\text{MCL} = \text{OSL} + \text{PML}$$

Where for the Summer (December to March), Winter (May to August) and Shoulder (other months):

$$\text{OSL} = (\text{Average daily load} \times \text{Average future expected spot price} \times \text{Participant Risk Adjustment Factor} \times \text{OS Volatility factor} \times (\text{GST} + 1)) \times 35 \text{ days}$$

$$\text{PML} = (\text{Average daily load} \times \text{Average future expected spot price} \times \text{Participant Risk Adjustment Factor} \times \text{PM Volatility factor} \times (\text{GST} + 1)) \times 7 \text{ days}$$

Taking a 1 MWh average daily load and assuming the inputs in Table 4.9 for each season for the Energex NSLP gives an estimated MCL of \$8,021.

However, as this applies for a rolling 42 days it actually covers 42 MWh of retailer purchases. Hence the portion of the MCL applicable to each MWh in the Energex NSLP is  $\$8,021/42 = \$190.97/\text{MWh}$ .

The cost of funding a bank guarantee for the MCL associated with the single MWh is assumed to be a 2.5 percent annual charge for 42 days or  $2.5\% \times (42/365) = 0.288$  percent. Applying this funding cost to the single MWh charge of \$190.97 gives \$0.55/MWh for the Energex NSLP.

The components of the AEMO prudential costs for Ergon are shown in Table 4.10.

**Table 4.9** AEMO prudential costs for Energex NSLP – 2022-23

Factor	Summer	Winter	Shoulder
Load Weighted Expected Price (\$/MWh, nominal)	\$104.22	\$50.33	\$49.04
Participant Risk Adjustment Factor	1.6048	1.2677	1.3404
OS Volatility factor	1.50	1.35	1.41
PM Volatility factor	2.71	1.81	1.88
OSL	\$12,236	\$3,733	\$4,131
PML	\$2,447	\$747	\$826
MCL	\$14,683	\$4,480	\$4,957
Average MCL		\$8,021	
<b>AEMO prudential cost (\$/MWh, nominal)</b>		<b>\$0.55</b>	

*Source: ACIL Allen analysis of AEMO data*

**Table 4.10** AEMO prudential costs for Ergon NSLP – 2022-23

Factor	Summer	Winter	Shoulder
Load Weighted Expected Price (\$/MWh, nominal)	\$104.22	\$50.33	\$49.04
Participant Risk Adjustment Factor	1.2893	1.1423	1.1865
OS Volatility factor	1.50	1.35	1.41
PM Volatility factor	2.71	1.81	1.88
OSL	\$8,811	\$3,194	\$3,441
PML	\$1,762	\$639	\$688
MCL	\$10,574	\$3,832	\$4,129
Average MCL		\$6,165	
<b>AEMO prudential cost (\$/MWh, nominal)</b>		<b>\$0.42</b>	

*Source: ACIL Allen analysis of AEMO data*

### Hedge prudential costs

ACIL Allen has relied on the futures market to determine hedging costs. The futures market includes prudential obligations by requiring entities to lodge initial margins (we assume cash) when contracts are purchased or sold. We understand that the cash that is lodged as an initial margin receives a money market related return which offsets some of the funding costs. The current money market rate is 0.10 per cent. Additional margin calls may apply where contracts move unfavourably for the purchaser or seller. However, as these may be favourable or unfavourable, we have assumed that they average out over time.

We understand that the initial margin is set based on three parameters being:

- the price scanning range (PSR) expressed as a percentage of the contract face value and currently set at around 8 percent on average for a base contract, 14 percent for a peak contract and 19 percent for a cap contract
- the intra monthly spread charge currently set at \$12,300 for a base contract of 1 MW for a quarter, \$13,600 for a peak contract and \$5,900 for a cap contract
- the spot isolation rate currently set at \$1,500 for a base contract, \$1,500 for a peak contract and \$600 for a cap contract.

Using the annual average futures price and applying the above factors gives an average initial margin for each quarter (rounded up) as shown for Queensland in Table 4.11. This is divided by the average hours in a quarter. Then applying the assumed funding cost of 7.22 per cent but adjusted for an assumed 0.10 per cent return on cash lodged with the clearing (giving a net funding cost of 7.12 percent) results in the prudential cost per MWh for each contract type.

Average initial margins for Queensland using the average contract prices and initial margin parameters results in a prudential cost per MWh for each contract type as shown in the right column of Table 4.11.

**Table 4.11** Hedge Prudential funding costs by contract type – Queensland 2022-23

Contract Type	Average contract price	Initial margin (rounded up to nearest \$1000)	Prudential cost per MWh
Base	\$54.43	\$25,000	\$0.81
Peak	\$85.77	\$26,000	\$1.97
Cap	\$11.79	\$12,000	\$0.39

Source: ACIL Allen analysis of ASX Energy and RBA data

However, the hedge model used is designed to conservatively cover all load at the extremes and so results in an over-contracted position against the average load. The volume of hedges (MWh) in each category have been calculated as a proportion of the average annual load in each jurisdiction NSLP to give a proportional factor. The product of the prudential cost per MWh for each contract type and the proportion of each contract in the hedge model profile provides the total hedge prudential cost per MWh associated with each contract type. These are then summed to establish the total hedge prudential costs for the Energex and Ergon NSLPs as shown in Table 4.12 and Table 4.13 respectively.

**Table 4.12** Hedge Prudential funding costs for ENERGEX NSLP – 2022-23

Contract Type	Prudential cost per MWh	Proportion of contract hedged against average annual energy	Hedge prudential cost per MWh
Base	\$0.81	1.1219	\$0.91
Peak	\$1.97	0.0184	\$0.04
Cap	\$0.39	1.5771	\$0.62
<b>Total cost</b>		<b>\$1.56</b>	

Source: ACIL Allen analysis

**Table 4.13** Hedge Prudential funding costs for ERGON NSLP – 2022-23

Contract Type	Prudential cost per MWh	Proportion of contract hedged against average annual energy	Hedge prudential cost per MWh
Base	\$0.81	1.1295	\$0.92
Peak	\$1.97	0.0001	\$0.00
Cap	\$0.39	1.0014	\$0.39
<b>Total cost</b>		<b>\$1.31</b>	

*Source: ACIL Allen analysis*

### Total prudential costs

Adding the AEMO and hedge prudential costs gives a total prudential requirement for 2022-23 as set out in Table 4.14. Prudential costs for 2022-23 are higher than 2021-22 due to higher hedge prices and higher expected price volatility across 2022-23.

**Table 4.14** Total prudential costs (\$/MWh, nominal) – 2022-23

Jurisdiction	2021-22	2022-23
Energex NSLP	\$1.67	\$2.11
Ergon NSLP	\$1.36	\$1.73

*Source: ACIL Allen analysis*

#### 4.4.4 Reliability and Emergency Reserve Trader (RERT)

As with the ancillary services, we take the RERT costs as published by AEMO for the 12-month period prior to the Draft Determination (and this will be updated for the Final Determination).

AEMO activated the RERT for 15 MW in Queensland on 25 May 2021, in response to a forecast Lack of Reserve (LOR) 2 condition which developed into an actual LOR 2 and a forecast LOR 3 condition. This was the result of the loss of several generating units due to the fire at unit 4 of Callide. AEMO reported the costs of this activation to be \$452,881. When dividing this value by the total energy requirements in Queensland, the cost of the RERT is about one cent per MWh.

#### 4.4.5 Summary of estimated total other costs

Adding these component costs gives a total other cost requirement as set out in Table 4.15 and Table 4.16, for the 2022-23 Draft Determination and is compared with the costs for 2021-22.

**Table 4.15** Total of other costs (\$/MWH, nominal) – Energex NSLP – 2022-23

Cost category	2021-22	2022-23
NEM management fees	\$0.49	\$0.67
Ancillary services	\$0.41	\$1.26
Hedge and spot prudential costs	\$1.67	\$2.11
Reserve and Emergency Reserve Trader	\$0.00	\$0.01
<b>Total</b>	<b>\$2.57</b>	<b>\$4.05</b>

*Source: ACIL Allen analysis*

**Table 4.16** total of other costs (\$/MWH, nominal) – Ergon NSLP – 2022-23

Cost category	2021-22	2022-23
NEM management fees	\$0.49	\$0.67
Ancillary services	\$0.41	\$1.26
Hedge and spot prudential costs	\$1.36	\$1.73
Reserve and Emergency Reserve Trader	\$0.00	\$0.01
<b>Total</b>	<b>\$2.26</b>	<b>\$3.67</b>

*Source: ACIL Allen analysis*

## 4.5 Estimation of energy losses

The methodology up to this point produces price estimates at the Queensland regional reference node (RRN). Prices at the Queensland RRN must be adjusted for losses to the end-users. Distribution loss factors (DLF) for Energex and Ergon Energy east zone and average Marginal Loss Factors (MLF) for transmission losses from the reference node to major supply points in the distribution networks are applied.

For the Draft Determination, the losses for 2022-23 are based on the estimates for 2021-22 Final Determination. Although AEMO recently published the preliminary MLF estimates for 2022-23 in late December 2021 these have not been included in the Draft Determination given their preliminary nature.

The MLFs and DLFs used to estimate losses for the Final Determination for 2022-23 will be based on the 2022-23 MLFs and DLFs to be published by AEMO in early April 2022.

The estimation of transmission and distribution loss factors for the settlement classes to be used in calculating energy costs for 2022-23 is shown in Table 4.17.

**Table 4.17** Estimated transmission and distribution losses

	2021-22			2022-23		
	Distribution loss factor (DLF)	Transmission marginal loss factor (MLF)	Total loss factors (MLFxDLF)	Distribution loss factor (DLF)	Transmission marginal loss factor (MLF)	Total loss factors (MLFxDLF)
Energex – NSLP - residential and small business	1.059	1.006	1.066	1.059	1.006	1.066
Energex – Controlled load tariff 9000 (31)	1.059	1.006	1.066	1.059	1.006	1.066
Energex – Controlled load tariff 9100 (33)	1.059	1.006	1.066	1.059	1.006	1.066
Energex – NSLP - unmetered supply	1.059	1.006	1.066	1.059	1.006	1.066
Ergon Energy – NSLP - CAC and ICC	1.036	0.986	1.022	1.036	0.986	1.022
Ergon Energy - NSLP - SAC demand and street lighting	1.077	0.986	1.062	1.077	0.986	1.062
Energex – Small business primary load control tariff	1.059	1.006	1.066	1.059	1.006	1.066
Ergon – Large business primary and secondary load control tariffs	1.077	0.986	1.062	1.077	0.986	1.062

*Source: ACIL Allen analysis of AEMO data*

As described by AEMO<sup>15</sup>, to arrive at prices at the customer terminal (price at load connection point) the MLF and DLF are applied to the prices at the regional reference node (RRN) as follows:

$$Price\ at\ load\ connection\ point = RRN\ Spot\ Price * (MLF * DLF)$$

<sup>15</sup> See Page 23 of the AEMO publication *Treatment of loss factors in the national electricity market- July 2012*

## 4.6 Summary of estimated energy costs

Drawing together the analyses and estimates from the previous sections of this report, ACIL Allen’s estimates of the 2022-23 total energy costs (TEC) for the Draft Determination for each of the profiles are presented in Table 4.18.

**Table 4.18** Estimated TEC for 2022-23 Draft Determination

Settlement class	WEC at Qld reference node (\$/MWh)	Renewable energy costs at Qld reference node (\$/MWh)	Other costs Qld reference node (\$/MWh)	Total transmission and distribution loss factor (MLF x DLF)	Network losses (\$/MWh)	TEC at the customer terminal (\$/MWh)	Change from 2021-22 Final Determination (\$/MWh)	Change from 2021-22 Final Determination (%)
Energex – NSLP - residential and small business	\$86.74	\$13.24	\$4.05	1.066	\$6.87	<b>\$110.90</b>	\$19.07	20.77%
Energex – Controlled load tariff 9000 (31)	\$66.29	\$13.24	\$4.05	1.066	\$5.52	<b>\$89.10</b>	\$12.65	16.55%
Energex – Controlled load tariff 9100 (33)	\$70.66	\$13.24	\$4.05	1.066	\$5.80	<b>\$93.75</b>	\$15.71	20.13%
Energex – NSLP - unmetered supply	\$86.74	\$13.24	\$4.05	1.066	\$6.87	<b>\$110.90</b>	\$19.07	20.77%
Ergon Energy – NSLP - CAC and ICC	\$77.43	\$13.24	\$3.67	1.022	\$2.08	<b>\$96.42</b>	\$15.52	19.19%
Ergon Energy - NSLP - SAC demand and street lighting	\$77.43	\$13.24	\$3.67	1.062	\$5.85	<b>\$100.19</b>	\$16.12	19.18%
Energex – Small business primary load control tariff	\$70.20	\$13.24	\$4.05	1.066	\$5.77	<b>\$93.26</b>	\$11.04	13.43%
Ergon – Large business primary and secondary load control tariffs	\$70.66	\$13.24	\$3.67	1.062	\$5.43	<b>\$93.00</b>	\$15.58	20.13%

Source: ACIL Allen analysis

# AEMC 2021 Residential electricity price trends report

A

The AEMC's report, *2021 Residential Electricity Price Trends*, was released in November 2021 (the AEMC report). The AEMC report does not form part of any regulatory determination process but has the purpose of providing consumers and governments with an understanding of the cost components of the electricity supply chain and the expected trends of the components for the majority of customers in each region.

Provided below are some key differences in the approach adopted by the AEMC compared with ACIL Allen's methodology – noting that the AEMC report provides a high-level summary of the methodology.


## A.1 Wholesale energy costs

The AEMC's approach to estimating wholesale energy costs is broadly similar to the approach adopted by ACIL Allen. However, there are some key differences:

- Demand profiles:
  - It is ACIL Allen's understanding the AEMC does not adjust the historic NSLPs to take into account changes in the shape in the future due to further uptake of rooftop PV.
  - If this understanding is correct, then not adjusting the profiles will result in lower wholesale costs estimates (all other things equal).
  - It also appears that the AEMC aggregate the NSLPs within the New South Wales region to produce a state-based NSLP, and in the case of Queensland aggregate the NSLP and control load produce an aggregate WEC.
- Spot market modelling:
  - The AEMC appears to use historic bids (offer curves) when undertaking its spot price modelling. These appear to be adjusted for assumed changes in underlying costs (such as fuel prices) from the latest available ESOO. ACIL Allen's *PowerMark* uses dynamic bidding (based on game theory) to account of changes in bidding behaviour incentivised by changes in market conditions (such as the addition of renewable capacity between now and 2022-23, as well as changes in underlying costs). AEMC acknowledges that bidding behaviour may change in the future and therefore affect their results.
- Hedge portfolio:
  - AEMC use a portfolio of quarterly base, peak and cap hedges to cover the NSLP, as does ACIL Allen, but do not provide the mix of these products or the extent that the portfolio of hedges covers the NSLP profile.
- Hedge or contract prices:
  - AEMC use a 2-year build-up of hedges using ASX Energy contract price data up to October 2021.
  - It appears AEMC's portfolio build-up is assumed to be completed by April 2022, as is ACIL Allen's for the Final Determination.

- This means that six months of actual ASX Energy prices are unable to be included in the AEMC analysis for 2022-23 (with the six-month period being October 2021 to end of March 2022).
- AEMC do not use the observable trade volumes as the weights to calculate the weighted average cost of each product, and instead use an exponential build-up of the portfolio of hedges.
- For the six months of missing ASX Energy contract data, the AEMC have used their modelled spot price outcomes as a substitute for contract prices. This means that in deriving the final estimate of the contract prices for each quarterly product for 2022-23, AEMC is missing at least, an assumed, 60 per cent of ASX Energy trade volumes and corresponding prices, and is using their modelled spot prices to represent the missing 60 per cent of trade volumes and contract prices.
- Rather than pre-specifying or forcing a particular pattern in the hedge book build up, ACIL Allen uses all trades back to the first trade recorded by ASX Energy for the given product, which generally more closely reflects, in practice, how retailers build up their portfolio of hedging contracts over time. We have noted in earlier reports that the cumulative shape in actual volume of trades can be quite different to an exponential curve in some years.
- Forcing an exponential book build and using a different weighting between actual ASX Energy prices and modelled spot prices could yield a very different result.
- This is the key difference between our methodology and the AEMC methodology for estimating the WEC:
  - We use actual contract data because the final estimates of the WEC will be derived in April 2022 for the Final Determination, whereas AEMC had to make their final estimates at the beginning of October 2021 (so in effect the AEMC has had to fill in a contract price and volume data gap of six months with projected spot prices). For the Draft Determination we do not explicitly predict the volume or price level of trades in contracts between January 2022 and April 2022 – instead, we simply close the contract data as of 21 January 2022.
- Wholesale costs:
  - Given the continued upward trend in 2022-23 contract prices since the beginning of October 2021, the projected wholesale costs presented in the AEMC report for 2022-23 are about \$12/MWh lower than those of this Draft Determination for Queensland.

**Figure A.1** Total wholesale costs (\$/MWh, nominal)



Source: ACIL Allen analysis and AEMC

- ACIL Allen maintains the view that there is no net benefit in filling in the missing contract data for the Draft Determination since the actual data will be available for the Final Determination. The wholesale costs estimated for the Final Determination may well be different to those of the Draft Determination depending on volume and price level of trades in contracts that occur between the Draft and Final Determination. If actual contracts continued to be traded at volumes observed in previous years, and contract

prices increase further, between the Draft Determination and the Final Determination, then a further increase in the WECs would be expected for the Final Determination.

- It is also worth noting that the AEMC revised upwards its wholesale cost estimates for 2021-22 in its latest report (compared with its December 2020 report). For example, for south-east Queensland, the wholesale cost estimates for 2021-22 have increased from about \$61/MWh to \$85/MWh. This is important to note because one of the headlines from the latest AEMC report is that prices in Queensland will decline between 2021-22 and 2022-23 due to reducing wholesale costs – which is in contrast to our analysis.

**Melbourne**

Level 9, 60 Collins Street  
Melbourne VIC 3000 Australia  
+61 3 8650 6000

**Sydney**

Level 9, 50 Pitt Street  
Sydney NSW 2000 Australia  
+61 2 8272 5100

**Brisbane**

Level 15, 127 Creek Street  
Brisbane QLD 4000 Australia  
+61 7 3009 8700

**Canberra**

Level 6, 54 Marcus Clarke Street  
Canberra ACT 2601 Australia  
+61 2 6103 8200

**Perth**

Level 12, 28 The Esplanade  
Perth WA 6000 Australia  
+61 8 9449 9600

**Adelaide**

167 Flinders Street  
Adelaide SA 5000 Australia  
+61 8 8122 4965

ACIL Allen Pty Ltd  
ABN 68 102 652 148

[acilallen.com.au](http://acilallen.com.au)